



**BUREAU  
VERITAS**

# TEST REPORT

## EN 50549-1:2019

**Requirements for generating plants to be connected in parallel  
with distribution networks - Part 1-1:  
Connection to a LV distribution network - Generating plants up  
to and including Type B**

Report reference number ..... : PV2107WDG0438

Date of issue ..... : 2021-10-13

Total number of pages ..... : 140

Testing laboratory name ..... : Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch

Address ..... : No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City,  
Guangdong Province, 523942, People's Republic of China

Accreditation ..... :



Applicant's name ..... : AISWEI New Energy Technology(Jiangsu) Co.,Ltd

Address ..... : Building 9, No.198 Xiangyang Road, 215011 Suzhou, P.R.China

### Test specification

Standard..... : EN 50549-1:2019

Test Report Form No. .... : EN 50549-1 VER.0

TRF Originator ..... : Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch

Master TRF ..... : Dated 2019-12-11

Test item description..... : Solar Inverter

Trademark..... :





Model / Type ..... : ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2,  
ASW45K-LT-G2, ASW50K-LT-G2,

This report is governed by, and incorporates by reference, CPS Conditions of Service as posted at the date of issuance of this report at <http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions> and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. Measurement uncertainty is only provided upon request for accredited tests. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence or if you require measurement uncertainty; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.

<b>Ratings .....</b>	<b>ASW30K-LT-G2</b>	<b>ASW33K-LT-G2</b>
Max. input DC voltage [V] .....	Max.1100V	
Input DC voltage range [V].....	200-1000V	
Input DC current [A] .....	3 * 26,0	3 * 26,0
Output AC voltage [V] .....	3/N/PE ~ 400V, 50Hz	
Output AC current [A].....	50,0	55,0
Nominal Output power [kW] .....	30,0	33,0
Maximum Output power [kVA] .....	30,0	33,0
<b>Ratings .....</b>	<b>ASW36K-LT-G2</b>	<b>ASW40K-LT-G2</b>
Max. input DC voltage [V] .....	Max.1100V	
Input DC voltage range [V].....	200-1000V	
Input DC current [A] .....	3 * 26,0	4 * 26,0
Output AC voltage [V] .....	3/N/PE ~ 400V, 50Hz	
Output AC current [A].....	60,0	66,7
Nominal Output power [kW] .....	36,0	40,0
Maximum Output power [kVA] .....	36,0	40,0
<b>Ratings .....</b>	<b>ASW45K-LT-G2</b>	<b>ASW50K-LT-G2</b>
Max. input DC voltage [V] .....	Max.1100V	
Input DC voltage range [V].....	200-1000V	
Input DC current [A] .....	4 * 26,0	5 * 26,0
Output AC voltage [V] .....	3/N/PE ~ 400V, 50Hz	
Output AC current [A].....	75,0	80,0
Nominal Output power [kW] .....	45,0	50,0
Maximum Output power [kVA] .....	45,0	50,0



<b>Testing Location</b> .....	<b>AISWEI New Energy Technology(Jiangsu) Co.,Ltd</b>		
Address .....	Building 9,No.198 Xiangyang Road,215011 Suzhou,P.R.China		
Tested by (name and signature)..... :	Sean Tu		
Approved by (name and signature)..... :	Ken Chan		
<b>Manufacturer's name</b> ..... :	<b>AISWEI New Energy Technology(Jiangsu) Co.,Ltd</b>		
Manufacturer address .....	Building 9,No.198 Xiangyang Road,215011 Suzhou,P.R.China		
<b>Factory's name</b> ..... :	<b>AISWEI New Energy Technology (Yangzhong) Co., Ltd</b>		
Factory address .....	No.588 Gangxing Road,Yangzhong, Jiangsu P.R.China		

<b>Document History</b>			
<b>Date</b>	<b>Internal reference</b>	<b>Modification / Change / Status</b>	<b>Revision</b>
2021-10-13	Sean Tu	Initial report was written	0
Supplementary information:			

**Test items particulars**

Equipment mobility ..... : Permanent connection  
 Operating condition ..... : Continuous  
 Class of equipment ..... : Class I  
 Protection against ingress of water .. : IP65 according to EN 60529  
 Mass of equipment [kg] ..... : Approx. 43,0kg

**Test case verdicts**

Test case does not apply  
 to the test object ..... : N/A  
 Test item does meet  
 the requirement ..... : P(ass)  
 Test item does not meet  
 the requirement ..... : F(ail)

**Testing**

Date of receipt of test item ..... : 2021-07-29  
 Date(s) of performance of test ..... : 2021-07-29 to 2021-09-12

**General remarks:**

The test result presented in this report relate only to the object(s) tested. The report shall state compliance of the tested objects with the requirements of EN 50549-1. This report shall not be reproduced in part or in full without the written approval of the issuing testing laboratory.

"(see Annex #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

**This Test Report consists of the following documents:**

1. Test Report
  - 4.4 Normal operating range
  - 4.5 Immunity to disturbances
  - 4.6 Active response to frequency deviation
  - 4.7 Power response to voltage variations and voltage changes
  - 4.8 EMC and power quality
  - 4.9 Interface protection
  - 4.10 Connection and starting to generate electrical power
  - 4.11 Ceasing and reduction of active power on set point
  - 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch
2. Annex No. 1 – Datasheet of the relay
3. Annex No. 2 – Pictures of the unit
4. Annex No. 3 – Test equipment list

Copy of marking plate



Model: ASW30K-LT-G2

Max. input voltage	d.c. 1100V
MPP voltage range	d.c. 200-1000V
Max. input current	d.c. 3x26A
Isc PV(absolute maximum)	d.c. 3x40A
Rated grid voltage	3/N/PE ~ 230/400V
Rated grid frequency	50Hz
Rated AC output active power	30kW
Max. AC output apparent power	30kVA
Max. continuous output current	a.c. 50A
Adjustable cos( $\phi$ )	0.8ind...0.8cap
Operating temperature range	-25...+60°C
Topology	Non-isolated
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV), III(MAINS)



AISWEI New Energy Technology (Jiangsu) Co., Ltd.  
Hotline: +86 400 801 9996  
Web: www.aiswei-tech.com  
Add.: No.198 Xiangyang Road, Suzhou 215011,China

532-00579-02

Made in China



Model: ASW33K-LT-G2

Max. input voltage	d.c. 1100V
MPP voltage range	d.c. 200-1000V
Max. input current	d.c. 3x26A
Isc PV(absolute maximum)	d.c. 3x40A
Rated grid voltage	3/N/PE ~ 230/400V
Rated grid frequency	50Hz
Rated AC output active power	33kW
Max. AC output apparent power	33kVA
Max. continuous output current	a.c. 55A
Adjustable cos( $\phi$ )	0.8ind...0.8cap
Operating temperature range	-25...+60°C
Topology	Non-isolated
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV), III(MAINS)



AISWEI New Energy Technology (Jiangsu) Co., Ltd.  
Hotline: +86 400 801 9996  
Web: www.aiswei-tech.com  
Add.: No.198 Xiangyang Road, Suzhou 215011,China

532-00578-02

Made in China

Copy of marking plate



Model: ASW36K-LT-G2

Max. input voltage	d.c. 1100V
MPP voltage range	d.c. 200-1000V
Max. input current	d.c. 3x26A
Isc PV(absolute maximum)	d.c. 3x40A
Rated grid voltage	3/N/PE ~ 230/400V
Rated grid frequency	50Hz
Rated AC output active power	36kW
Max. AC output apparent power	36kVA
Max. continuous output current	a.c. 60A
Adjustable cos( $\phi$ )	0.8ind...0.8cap
Operating temperature range	-25...+60°C
Topology	Non-isolated
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV), III(MAINS)



AISWEI New Energy Technology (Jiangsu) Co., Ltd.  
Hotline: +86 400 801 9996  
Web: www.aiswei-tech.com  
Add.: No.198 Xiangyang Road, Suzhou 215011,China

532-00577-02

Made in China



Model: ASW40K-LT-G2

Max. input voltage	d.c. 1100V
MPP voltage range	d.c. 200-1000V
Max. input current	d.c. 4x26A
Isc PV(absolute maximum)	d.c. 4x40A
Rated grid voltage	3/N/PE ~ 230/400V
Rated grid frequency	50Hz
Rated AC output active power	40kW
Max. AC output apparent power	40kVA
Max. continuous output current	a.c. 66.7A
Adjustable cos( $\phi$ )	0.8ind...0.8cap
Operating temperature range	-25...+60°C
Topology	Non-isolated
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV), III(MAINS)



AISWEI New Energy Technology (Jiangsu) Co., Ltd.  
Hotline: +86 400 801 9996  
Web: www.aiswei-tech.com  
Add.: No.198 Xiangyang Road, Suzhou 215011,China

532-00576-02


Made in China

## Copy of marking plate



Model: ASW45K-LT-G2

Max. input voltage	d.c. 1100V
MPP voltage range	d.c. 200-1000V
Max. input current	d.c. 4x26A
Isc PV(absolute maximum)	d.c. 4x40A
Rated grid voltage	3/N/PE ~ 230/400V
Rated grid frequency	50Hz
Rated AC output active power	45kW
Max. AC output apparent power	45kVA
Max. continuous output current	a.c. 75A
Adjustable cos( $\phi$ )	0.8ind...0.8cap
Operating temperature range	-25...+60°C
Topology	Non-isolated
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV), III(MAINS)



AISWEI New Energy Technology (Jiangsu) Co., Ltd.  
 Hotline: +86 400 801 9996  
 Web: www.aiswei-tech.com  
 Add.: No.198 Xiangyang Road, Suzhou 215011,China

532-00575-02

Made in China



Model: ASW50K-LT-G2

Max. input voltage	d.c. 1100V
MPP voltage range	d.c. 200-1000V
Max. input current	d.c. 5x26A
Isc PV(absolute maximum)	d.c. 5x40A
Rated grid voltage	3/N/PE ~ 230/400V
Rated grid frequency	50Hz
Rated AC output active power	50kW
Max. AC output apparent power	50kVA
Max. continuous output current	a.c. 80A
Adjustable cos( $\phi$ )	0.8ind...0.8cap
Operating temperature range	-25...+60°C
Topology	Non-isolated
Ingress protection	IP65
Protective class	I
Overvoltage category	II(PV), III(MAINS)



AISWEI New Energy Technology (Jiangsu) Co., Ltd.  
 Hotline: +86 400 801 9996  
 Web: www.aiswei-tech.com  
 Add.: No.198 Xiangyang Road, Suzhou 215011,China

532-00574-02

Made in China



### General product information:

The Solar Inverter converts DC voltage into AC voltage.

The Solar Inverter is three phase type and DC input supply by PV array.

The input and output are protected by Varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.

### Description of the electrical circuit:

The internal control is redundant built. It consists of Master DSP (U523) and Slave DSP (U546).

The Master DSP (U523) control the relays by switching signals; measures the PV voltage, PV current, Bus voltage, grid voltage, frequency, AC current, injected DC and the array insulation resistance to ground. In addition it tests the current sensors and the RCMU circuit before each start up.

The Slave DSP (U546) can switch off the relays independently, and communicate with the master DSP (U523) each other to monitor the master DPS (U523).

The current is measured by a current sensor. The AC current signal and the injected DC current signal are sent to the DSP (U523). The DSP (U523) tests and calibrates before each start up all current sensors.

The unit provides two relays in series in all output conductors. When single fault applied to one relay, alarm an error code in display panel, another redundant relay provides basic insulation maintained between the PV array and the mains. All the relays are tested before each start up.




Figure 1 – Block diagram

**Differences of the models:**

The models ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2, ASW45K-LT-G2 and ASW50K-LT-G2 are identical in hardware and software, and the output power derated by software.

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

**The product was tested on:**

Hardware: V1.0

Software: V1.0

### General remarks:

The test results presented in this report relate only to the object(s) tested.

This document may be published or passed on in full only. Extraction of parts needs the written permission of Bureau Veritas Consumer Products Services GmbH.

"(see Annex #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.


The following suffixes are used for variables in tables and figures:

- "P<sub>n</sub>" for the nominal active power:  
 $P_n = U_n \times I_n \times \cos \varphi_n$  (single-Phase);  $P_n = \sqrt{3} U_n \times I_n \times \cos \varphi_n$  (three-Phase)
- "P<sub>M</sub>" for the momentary power
- "(c)" for over-excited
- "(i)" for under-excited


### Active and reactive power:

The regarded system of the voltage and current vectors is the load view (Figure 2):

- If the inverter feeds to the grid the active power is measured with negative sign. For the sake of reading the document the measured active infeed power has a positive sign



- If the inverter consumes inductive reactive power the reactive power is marked "inductive" or has a positive sign.
- If the inverter consumes capacitive reactive power the reactive power is marked "capacitive" or has a negative sign.



**Figure 2**

**Default interface protection settings according EN 50549-1:2019:**

Parameter	Max. disconnection time	Min. operate time	Trip value
Over voltage – stage 1	3,0 s	0,1 s	230V +15% (264,5 V)
Over voltage – stage 2	0,2 s	0,1 s	230V +25% (287,5 V)
Under voltage – stage 1	5,0 s	0,1 s	230V -20% (184V)
Under voltage – stage 2	2,0 s	0,1 s	230V -50% (115V)
Over frequency – stage 1	0,5 s	0,3 s	51,5 Hz
Over frequency – stage 2	0,2 s	0,1 s	52,0 Hz
Under frequency– stage 1	0,5 s	0,3 s	47,5 Hz
Under frequency– stage 2	0,2 s	0,1 s	47,0 Hz
Reconnection settings for voltage	0,85 U <sub>n</sub> ≤ U ≤ 1,10 U <sub>n</sub>		
Connection settings for frequency (Normal operational start-up)	49,5 Hz ≤ f ≤ 50,1 Hz		
Reconnection settings for frequency (Automatic reconnection after tripping)	49,5 Hz ≤ f ≤ 50,2 Hz		
Reconnection time	≥ 60 s		
Active power gradient after reconnection	10%P <sub>n</sub> /min		
Permanent DC-injection	0,5% of rated inverter output current or 20mA		
Loss of mains according EN 62116	Inverter shall disconnect within 2 s.		
<p>The stated currents and voltages are 'true r.m.s.'-values.            The voltages in this table are            - phase-to-neutral in 230 V single phase systems and 230/400 V systems,            - phase-to-phase in a multiphase 230 V system.</p>			
<p>Tolerances on trip values:</p> <ul style="list-style-type: none"> <li>- Voltage: ± 1% of U<sub>n</sub></li> <li>- Frequency: ± 0,05 Hz</li> <li>- Disconnection time : ± 10%</li> </ul>			

### EN 50549:2019, clause 4: Tests

Clause	Test requirement (According to table C.1)	Result
4.4	Normal operating range	P
4.5	Immunity to disturbances	P
4.6	Active response to frequency deviation	P
4.7	Power response to voltage variations and voltage changes	P
4.8	EMC and power quality	P
4.9	Interface protection	P
4.10	Connection and starting to generate electrical power	P
4.11	Ceasing and reduction of active power on set point	P
4.12	Remote information exchange	N/A
4.13	Requirements regarding single fault tolerance of interface protection system and interface switch	P

### EN 50549-1:2019: Normal operating range

Clause	Test requirement	Test procedure according standard	Result
4.4.2	Power response to over-frequency	EN 50438, Annex D.3.1	P
4.4.3	Power response to under-frequency	G99/1-4, clause A.7.3.2	P
4.4.4	Continuous operating voltage range	EN 50438, Annex D.3.1	P


4.4.2 Operating frequency range			P	
4.4.4 Continuous operating voltage range				
Setting values	Over-voltage [V]:		253,0	
	Under-voltage [V]:		195,5	
	Over-frequency [Hz]:		51,5	
	Under-frequency [Hz]:		47,5	
<ul style="list-style-type: none"> <li>- Test 1: U = 195,5 V; f = 47,5 Hz; P = 1,00 S<sub>n</sub>; cosφ = 1; Period of test 30 minutes</li> <li>- Test 2: U = 195,5 V; f = 48,5 Hz; P = 1,00 S<sub>n</sub>; cosφ = 1; Period of test 30 minutes</li> <li>- Test 3: U = 253,0 V; f = 51,5 Hz; P = 1,00 S<sub>n</sub>; cosφ = 1; Period of test 30 minutes</li> <li>- Test 4: U = 230,0 V; f = 50,0 Hz; Voltage Phase jumps Change +20 degrees P = 1,00 S<sub>n</sub>; cosφ = 1</li> <li>- Test 5: U = 230,0 V; f = 50,0 to 50,5 Hz; RoCoF=1Hz/s; P = 1,00 S<sub>n</sub>; cosφ = 1; Period of test 0,5 seconds</li> </ul>				
<b>Test result: ASW50K-LT-G2</b>				
Test sequence	Voltage [V]	Frequency [Hz]	Output power [kW]	Cos φ
Test1	196,36	47,50	47,742	0,9998
Test2	196,41	48,50	47,754	0,9998
Test3	254,05	51,50	50,218	0,9992
Test4	233,28	50,00	50,289	0,9995
Test5	233,22	50,00	50,255	0,9995
<p><b>Note:</b></p> <p>Test method refer clause D.3.1 of EN 50438:2013.</p> <p>During the tests the interface protection was disabled.</p> <p>Operation at reduced power is allowed during test 1, equal to the maximum power that can be supplied on reaching the maximum output current limit (<math>P \geq 0,85 S_n</math>).</p> <p>During the sequence of test 3, automatic adjustment to reduce power in the case of over-frequency was disabled.</p> <p>The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.</p>				

#### 4.4.3 Minimal requirement for active power delivery at under-frequency

P

Test result: ASW50K-LT-G2

Graph of frequency a) to b) to c) to d) to e):



Test result:

	Switch to:				
5-min mean value (each)	a) 49,50 Hz	b) 49,00 Hz	c) 48,00 Hz	d) 47,60 Hz	e) 47,10 Hz
Frequency [Hz]:	49,50	49,00	48,00	47,60	47,10
Active power [kW]:	50,267	50,301	50,295	50,320	50,295
$\Delta P/P_n$ [%] :	0,534	0,602	0,590	0,640	0,590



**Assessment criterion:**

Test method refer clause A.7.3.2 of G99/1-4


The frequency should then be set to 49,5 Hz for 5 minutes. The output should remain at 100% of registered Capacity.

The frequency should then be set to 49,0 Hz and once the output has stabilised, held at this frequency for 5 minutes. The Active Power output must not be below 99% of registered Capacity.

The frequency should then be set to 48,0 Hz and once the output has stabilised, held at this frequency for 5 minutes. The Active Power output must not be below 97% of registered Capacity.

The frequency should then be set to 47,6 Hz and once the output has stabilised, held at this frequency for 5 minutes. The Active Power output must not be below 96.2% of registered Capacity.

The frequency should then be set to 47,1 Hz and held at this frequency for 20s. The Active Power output must not be below 95,0% of registered Capacity and the Synchronous Power Generating Module must not trip in less than the 20s of the test.



Maximum allowable power reduction in case of under-frequency

**Note:**

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

## EN 50549-1:2019: Immunity to disturbances

Clause	Test requirement	Test procedure according standard	Result
4.5.2	Rate of change of frequency (RoCoF) immunity	G99/1-4:2019, clause A.7.1.2.6	<b>P</b>
4.5.3	Low voltage ride through (LVRT)	VDE V 0124-100:2019-02 (Draft), clause 5.8.3.	<b>P</b>
4.5.4	High voltage ride through (HVRT)	VDE V 0124-100:2019-02 (Draft), clause 5.8.3.	<b>P</b>
4.7.4	Zero current mode for converter connected generating plants	VDE V 0124-100:2019-02 (Draft), clause 5.8.3.	<b>P</b>

4.5.2 Rate of change of frequency (ROCOF) immunity(default setting)				P
	Start Frequency	Change	End Frequency	Confirm no trip
Positive Frequency drift	49Hz	+2Hz/sec	51Hz	No trip
Negative Frequency drift	51Hz	-2Hz/sec	49Hz	No trip

**Note:**

Test method refer clause A.7.1.2.6 of G99/1-4:2019.

Hold for 10 s

Manufacturers considering new designs should allow for the RoCoF where stability is required to be increased to, up to 2Hz per second, as proposed in the new European network codes, which are expected to come into force over the period 2014/2015. Under these conditions RoCoF will cease to be an effective loss of mains protection and is unlikely to be permitted in future revisions of this document.

For the step change test the SSEG should be operated with a measureable output at the start frequency and then a vector shift should be applied by extending or reducing the time of a single cycle with subsequent cycles returning to the start frequency. The start frequency should then be maintained for a period of at least 10 seconds to complete the test. The SSEG should not trip during this test.

For frequency drift tests the SSEG should be operated with a measureable output at the start frequency and then the frequency changed in a ramp function at 0,95Hz per second to the end frequency. On reaching the end frequency it should be maintained for a period of at least 10 seconds. The SSEG should not trip during this test.

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.


<p>4.5.3 4.5.4 4.7.4</p>	<p><b>Low voltage ride through (LVRT)</b> <b>High voltage ride through (HVRT)</b> <b>Zero current mode for converter connected generating plants</b></p>	<p><b>P</b></p>
----------------------------------	--	-----------------

**General:**


If the voltage on the generator terminals falls below  $<0.8 U_n$  and if the generator terminals exceed the voltage of  $> 1.15 U_n$  (start of fault), generator must pass through voltage dips without any current being drawn into the grid Network operator (limited dynamic network support).

This requirement is met if, for a voltage dip below  $0.8 U_n$  or at a voltage increase above  $1.15 U_n$ , the injected current of the generating unit (s) and / or the memory 60 ms after occurrence of this voltage dip in any outer conductor 20% of the rated current  $I_r$  and does not exceed  $> 10\% I_r$  after 100 ms.

After the voltage returned to continuous operating voltage range of  $-15\% U_n$  to  $+10\% U_n$ , 90 % of pre fault power or available power whichever is the smallest shall be resumed as fast as possible, but at the latest within 1 s unless the DSO and the responsible party requires another value.



**Figure 6 — Low voltage ride through capability for non-synchronous generating technology**



**Figure 8 — Over-voltage ride through capability**

Test	Drop depth requirement [p.u. $U_n$ ]	Symmetry	Fault duration [ms]	Output power level		k-factor	Test no.
				P set point ( $P_{RE}$ / p.u.)	Q set point (Q / p.u.)		
1.A.1	0,03	Symmetrical	250	1,0	0,00	0	1.A.1
1.A.2				0,2			1.A.2
1.D.1		Asymmetrical		1,0			1.D.1
1.D.2				0,2			1.D.2
1.B.1		Single phase*		1,0			1.B.1
1.B.2				0,2			1.B.2
2.A.1	0,31	Symmetrical	1300	1,0	0,00	0	2.A.1
2.A.2				0,2			2.A.2
2.D.1		Asymmetrical		1,0			2.D.1
2.D.2				0,2			2.D.2
2.B.1		Single phase*		1,0			2.B.1
2.B.2				0,2			2.B.2
3.A.1	0,82	Symmetrical	3000	1,0	0,00	0	3.A.1
3.A.2				0,2			3.A.2
3.D.1		Asymmetrical		1,0			3.D.1
3.D.2				0,2			3.D.2
3.B.1		Single phase*		1,0			3.B.1
3.B.2				0,2			3.B.2
OV1	1,25	Symmetrical	100	1,0	0,00	0	OV1
OV2	1,20		5000	1,0			OV2
OV3	1,15		60000	1,0			OV3


**Note:**

For every kind of voltage dip a test without load has to be performed in order to prove that the test condition was fulfilled. The voltage has to drop to AT LEAST the defined depth level. An exception can be considered in case no current is supplied during dips.


\* Single phase = “choose Typ 7 at BV-Lab Studio”  $\cong$  LVRT Typ B

<b>Graph of FRT test one</b>				
<b>Test result:</b>				
<b>List of tests</b>	<b>Residual amplitude of phase-to-phase voltage [p.u. <math>U_n</math>]</b>	<b>Duration limit [ms]</b>	<b>Duration [ms]</b>	<b>Result</b>
<b><math>P_{E_{max}}</math> in %</b>	<b>100% <math>\pm</math>5%</b>			
1.A.1- Symmetrical	0,03	250 $\pm$ 20	267	Pass
1.D.1- Asymmetrical	0,03	250 $\pm$ 20	268	Pass
1.B.1- Single phase	0,03	250 $\pm$ 20	268	Pass
2.A.1- Symmetrical	0,31	1300 $\pm$ 20	1316	Pass
2.D.1- Asymmetrical	0,31	1300 $\pm$ 20	1316	Pass
2.B.1- Single phase	0,31	1300 $\pm$ 20	1317	Pass
3.A.1- Symmetrical	0,82	3000 $\pm$ 20	3011	Pass
3.D.1- Asymmetrical	0,82	3000 $\pm$ 20	3011	Pass
3.B.1- Single phase	0,82	3000 $\pm$ 20	3000	Pass
<b><math>P_{E_{max}}</math> in %</b>	<b>20% <math>\pm</math>5%</b>			
1.A.2- Symmetrical	0,03	250 $\pm$ 20	264	Pass
1.D.2- Asymmetrical	0,03	250 $\pm$ 20	264	Pass
1.B.2- Single phase	0,03	250 $\pm$ 20	267	Pass
2.A.2- Symmetrical	0,31	1300 $\pm$ 20	1316	Pass
2.D.2- Asymmetrical	0,31	1300 $\pm$ 20	1316	Pass
2.B.2- Single phase	0,31	1300 $\pm$ 20	1318	Pass
3.A.2- Symmetrical	0,82	3000 $\pm$ 20	3011	Pass
3.D.2- Asymmetrical	0,82	3000 $\pm$ 20	3011	Pass
3.B.2- Single phase	0,82	3000 $\pm$ 20	3011	Pass
<b><math>P_{E_{max}}</math> in %</b>	<b>100% <math>\pm</math>5%</b>			
OV1- Symmetrical	1,25	100 $\pm$ 20	103	Pass
OV2- Symmetrical	1,20	5000 $\pm$ 20	5011	Pass
OV3- Symmetrical	1,15	60000 $\pm$ 20	60001	Pass
<b>Test conditions:</b>				
Voltage simulator fall and rise time: < 20ms				
Used sample rate: 10 kHz				
<b>Note:</b>				
The test method refer to VDE V 0124-100:2020, clause 5.8.3.				
The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.				


**Test 1.A.1-Symmetrical fault ( $U/U_{nom} = 0,03$ );  $P = 100\% \pm 5\% P_n$**




**Test 1.D.1-Asymmetrical fault ( $U/U_{nom} = 0,03$ );  $P = 100\% \pm 5\% P_n$**



**Test 1.B.1-Single phase fault ( $U/U_{nom} = 0,03$ );  $P = 100\% \pm 5\% P_n$**




**Test 2.A.1-Symmetrical fault ( $U/U_{nom} = 0,31$ );  $P = 100\% \pm 5\% P_n$**







### hoTest 2.D.1- Asymmetrical fault ( $U/U_{nom} = 0,31$ ); $P = 100\% \pm 5\% P_n$




### Test 2.B.1-Single phase fault ( $U/U_{nom} = 0,31$ ); $P = 100\% \pm 5\% P_n$




**Test 3.A.1-Symmetrical fault ( $U/U_{nom} = 0,82$ );  $P = 100\% \pm 5\% P_n$**




**Test 3.D.1-Asymmetrical fault ( $U/U_{nom} = 0,82$ );  $P = 100\% \pm 5\% P_n$**




**Test 3.B.1-Single phase fault ( $U/U_{nom} = 0,82$ );  $P = 100\% \pm 5\% P_n$**




**Test 1.A.2-Symmetrical fault ( $U/U_{nom} = 0,03$ );  $P = 20\% \pm 5\% P_n$**




### Test 1.D.2-Asymmetrical fault (U/U<sub>nom</sub> = 0,03); P = 20% ±5% P<sub>n</sub>




### Test 1.B.2-Single phase fault (U/U<sub>nom</sub> = 0,03); P = 20% ±5% P<sub>n</sub>




### Test 2.A.2-Symmetrical fault ( $U/U_{nom} = 0,31$ ); $P = 20\% \pm 5\% P_n$




### Test 2.D.2-Asymmetrical fault ( $U/U_{nom} = 0,31$ ); $P = 20\% \pm 5\% P_n$




**Test 2.B.2-Single phase fault ( $U/U_{nom} = 0,31$ );  $P = 20\% \pm 5\% P_n$**




**Test 3.A.2-Symmetrical fault ( $U/U_{nom} = 0,82$ );  $P = 20\% \pm 5\% P_n$**




### Test 3.D.2-Asymmetrical fault ( $U/U_{nom} = 0,82$ ); $P = 20\% \pm 5\% P_n$




### Test 3.B.2-Single phase fault ( $U/U_{nom} = 0,82$ ); $P = 20\% \pm 5\% P_n$



### Test OV1-Symmetrical fault (U/U<sub>nom</sub> = 1,25); P = 100% ±5% P<sub>n</sub>




### Test OV2-Symmetrical fault (U/U<sub>nom</sub> = 1,20); P = 100% ±5% P<sub>n</sub>





Test OV3-Symmetrical fault ( $U/U_{nom} = 1,15$ );  $P = 100\% \pm 5\% P_n$



## EN 50549-1:2019: Active response to frequency deviation

Clause	Test requirement	Test procedure according standard	Result
4.6.1	Power response to over-frequency	VDE V 0124-100:2019-02 (Draft), clause 5.4.4	<b>P</b>
4.6.2	Power response to under-frequency	VDE V 0124-100:2019-02 (Draft), clause 5.4.6	<b>N/A</b>

<b>4.6.1 Power response to over-frequency</b>	<b>P</b>
---	----------

**Test result:**

1-min mean value [Hz]:	a) 50,00	b) 50,25	c) 50,70	d) 51,40	e) 50,70	f) 50,25	g) 50,00
------------------------	----------	----------	----------	----------	----------	----------	----------

1. Measurement a) to g): Active power output = 100%  $P_{E_{max}}$   
 $s=5\%$  (40%  $P_{ref}$  / Hz), threshold frequency for start/return: 50,2Hz

Frequency [Hz]:	50,00	50,25	50,70	51,40	50,70	50,25	50,00
$P_M$ [kW]:	N/A	49,00	40,00	26,00	40,00	49,00	N/A
$P_{E60}$ [kW]:	50,112	48,594	39,976	25,839	39,54	48,45	49,94
$\Delta P_{E60}/P_M$ [%]:	N/A	-0,813	-0,049	-0,322	-0,928	-1,108	N/A


**Test result:**

1-min mean value [Hz]:	a) 50,00	b) 50,25	c) 50,70	d) 51,40	e) 50,70	f) 50,25	g) 50,00
------------------------	----------	----------	----------	----------	----------	----------	----------


2. Measurement a) to g): Active power output 60% after freezing = 100%  $P_{E_{max}}$   
 $s=5\%$  (40%  $P_{ref}$  / Hz), threshold frequency for start/return: 50,2Hz

Frequency [Hz]:	50,00	50,25	50,70	51,40	50,70	50,25	50,00
$P_M$ [kW]:	N/A	29,00	20,00	6,00	20,00	29,00	N/A
$P_{E60}$ [kW]:	29,94	29,01	20,13	6,04	19,91	28,91	29,94
$\Delta P_{E60}/P_M$ [%]:	N/A	0,012	0,268	0,082	-0,180	-0,180	N/A


**Limit  $\Delta P/P_{1min}$ :**  $\pm 10\%$  of  $P_{E_{max}}$

**Graph of Measurement 1.: Active power output > 80%  $P_{E_{max}}$** 


**Graph of Measurement 2.:Active power output 40% and 60% after freezing > 80% P<sub>n</sub>**



**Graph of power gradient:**



**Test:**

The test is conducted for two powers. First, the test must start at a power =100%  $P_{E_{max}}$  ("Measurement 1"), and in a second test, for a power 60%  $P_{E_{max}}$  ("Measurement 2"). In the second test, after freezing of the  $P_M$ , the available active power output must be increased to a value =100%  $P_{E_{max}}$ , and after the network frequency of 50,2 Hz is fallen below, the rise of the active power gradient must be recorded.

Point g) must be held until the micro-generator is again feeding in with the active power output available.

**Assessment criterion:**

For  $f = 50,2$  Hz, the value of the  $P_M$  active power currently being generated is "frozen".

a) For adjustable micro-generators when:

- 1) the active power reduces between measuring points b) and f) given above with the set gradient  $P_M$  per Hz for a increasing frequency (or rises for a frequency decreasing again).
- 2) the maximum active power gradient occurring in point is less than the configured maximum active power per minute
- 3) the reaction value of the setpoint determined by the gradient characteristic curve does not differ from  $P_{E_{max}}$  by more than  $\pm 10\%$ .
- 4) the settling time is equal or below 2 s with an intentional delay set to zero

b) For partly adjustable micro-generators

- 1) when they behave as in a) within their adjustment range, and
- 2) when, outside the adjustable range, the power fed in on leaving the adjustment range remains constant until shutdown. Shutdown must be no later than at 51,5 Hz.

**Note:**

The test method refer to clause 5.4.4 of VDE V 0124-100:2019-02 (Draft).

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

## EN 50549-1:2019: Power response to voltage variations and voltage changes


Clause	Test requirement	Test procedure according standard	Result
4.7.2.2	Capabilities	--	<b>P</b>
4.7.2.3.2	Fix control modes ( <u>cos <math>\phi</math> setpoint mode</u> )	FGW TG3, Revision 25, clause 4.2.2	<b>P</b>
4.7.2.3.2	Fix control modes ( <u>Q setpoint mode, 48,43%</u> )	EN 50438:2013, Annex D.3.4.2.1	<b>P</b>
4.7.2.2	Q Response time	CEI 0-21:2019-04, Annex B.1.2.4	<b>P</b>
4.7.2.3.3	Voltage related control modes (Q (U) controls)	VDE AR 4105:2018-05, clause 5.7.2.4	<b>P</b>
4.7.2.3.4	Power related control modes (cos $\phi$ (P) curve)	VDE V 0124-100:2012, clause 5.3.6.4	<b>P</b>
4.7.3	Voltage related active power reduction (P(U) function)	CEI 0-21:2019-04, Annex B.1.3.1	<b>P</b>

4.7.2 Voltage support by reactive power				P
4.7.2.2 Capabilities				
4.7.2.3.2 Fix control modes (cos φ setpoint mode)				
<b>Test result: ASW30K-LT-G2</b>				
<b>PF = 0,8 / Inductive reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	3,087	-2,307	0,801	230,40
20%	5,923	-4,507	0,796	230,55
30%	9,012	-6,902	0,794	230,72
40%	12,010	-9,134	0,796	230,88
50%	15,006	-11,373	0,797	231,04
60%	17,980	-13,424	0,801	231,20
70%	21,098	-15,565	0,805	231,36
80%	23,903	-17,619	0,805	231,61
90%	24,312	-18,186	0,801	231,64
100%	24,364	-18,398	0,798	231,64
<b>PF = 0,8 / Capacitive reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	2,995	2,224	0,803	230,41
20%	6,014	4,432	0,805	230,58
30%	9,156	6,875	0,800	230,82
40%	12,184	9,291	0,795	231,01
50%	15,109	11,475	0,796	231,20
60%	18,021	13,740	0,795	231,38
70%	21,287	15,852	0,802	231,58
80%	24,223	17,980	0,803	231,76
90%	24,473	17,911	0,807	231,78
100%	24,517	17,879	0,808	231,78
<b>Cos phi=1 no reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	2,961	-0,161	0,999	230,43
20%	5,966	-0,071	0,999	230,61
30%	9,036	0,016	0,999	230,79
40%	12,102	0,109	0,999	230,97
50%	15,026	0,193	0,999	231,14
60%	17,958	0,267	0,999	231,31
70%	21,040	0,335	0,999	231,50
80%	24,042	0,333	0,999	231,68
90%	26,957	0,307	0,999	231,85
100%	29,841	0,246	0,999	232,02


<b>Test result: ASW50K-LT-G2</b>				
<b>PF = 0,8 / Inductive reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	5,095	-3,796	0,802	229,27
20%	10,182	-7,632	0,800	229,50
30%	15,254	-11,364	0,802	229,70
40%	20,180	-14,780	0,807	229,94
50%	25,081	-18,585	0,803	230,16
60%	30,394	-22,645	0,802	230,40
70%	35,411	-26,406	0,802	230,61
80%	40,379	-30,219	0,801	230,82
90%	40,392	-30,219	0,801	230,81
100%	40,399	-30,207	0,801	230,78
<b>PF = 0,8 / Capacitive reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	5,221	3,817	0,807	229,31
20%	10,240	7,605	0,803	229,54
30%	15,277	11,513	0,799	229,78
40%	20,451	15,239	0,802	230,02
50%	25,603	18,933	0,804	230,26
60%	30,352	22,840	0,799	230,50
70%	35,380	26,632	0,799	230,75
80%	40,223	30,163	0,800	230,99
90%	40,225	30,161	0,800	231,00
100%	40,227	30,158	0,800	231,02
<b>Cos phi=1 no reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	5,141	0,512	0,010	230,28
20%	10,205	0,522	0,017	230,52
30%	15,240	0,490	0,027	229,76
40%	20,286	0,484	0,014	229,80
50%	25,331	0,628	0,021	230,02
60%	30,359	0,862	0,018	229,47
70%	35,365	0,345	0,016	229,71
80%	40,391	0,148	0,020	229,95
90%	45,375	-0,503	0,021	230,17
100%	49,779	1,291	0,049	230,38
<b>Assessment criterion:</b>				
The power factor resulting in each of the measurement points between 20 % and 90 % of the nominal power is equal to or lower than 0,90 both in over excited and under excited operation.				
The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.				



**Diagram**



**ASW30K-LT-G2**



**ASW50K-LT-G2**

4.7.2 Voltage support by reactive power				P
4.7.2.2 Capabilities				
4.7.2.3.2 Fix control modes (Q setpoint mode, 48,43%)				
<b>Test result: ASW30K-LT-G2</b>				
<b>Inductive reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	3,058	-14,650	0,204	230,35
20%	6,013	-14,621	0,380	230,52
30%	8,912	-14,592	0,521	230,70
40%	12,041	-14,552	0,638	230,87
50%	15,057	-14,525	0,720	231,06
60%	17,991	-14,485	0,779	231,23
70%	20,904	-14,668	0,819	231,41
80%	23,806	-14,457	0,855	231,58
90%	26,542	-14,453	0,878	231,75
100%	26,737	-14,628	0,877	231,75
<b>Cos phi=1 no reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	2,961	-0,161	0,999	230,43
20%	5,966	-0,071	1,000	230,61
30%	9,036	0,016	1,000	230,79
40%	12,102	0,109	1,000	230,97
50%	15,026	0,193	1,000	231,14
60%	17,958	0,267	1,000	231,31
70%	21,040	0,335	1,000	231,50
80%	24,042	0,333	1,000	231,68
90%	26,957	0,307	1,000	231,85
100%	29,841	0,246	1,000	232,02
<b>Capacitive reactive power supply</b>				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	2,932	14,364	0,200	230,47
20%	6,052	14,416	0,387	230,62
30%	9,109	14,452	0,533	230,81
40%	12,184	14,518	0,643	231,00
50%	15,150	14,543	0,721	231,17
60%	18,152	14,497	0,781	231,34
70%	21,050	14,481	0,824	231,51
80%	24,180	14,692	0,855	231,68
90%	26,630	14,329	0,880	231,82
100%	26,630	14,329	0,880	231,82

Test result: ASW50K-LT-G2				
Inductive reactive power supply				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	4,981	-24,086	0,203	229,22
20%	9,945	-24,074	0,382	229,45
30%	15,106	-24,056	0,532	229,68
40%	19,949	-24,271	0,635	229,91
50%	24,914	-24,402	0,714	230,16
60%	30,387	-24,167	0,783	230,39
70%	35,420	-24,143	0,826	230,63
80%	40,433	-24,152	0,859	230,80
90%	44,275	-24,164	0,878	231,06
100%	44,279	-24,161	0,878	231,05
Capacitive reactive power supply				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	5,416	24,229	0,218	230,38
20%	10,511	24,164	0,399	230,60
30%	15,312	24,238	0,534	230,82
40%	20,631	24,214	0,649	231,05
50%	25,755	24,225	0,728	231,28
60%	30,322	24,290	0,780	231,50
70%	35,330	24,290	0,824	231,74
80%	40,349	24,287	0,857	231,97
90%	44,068	24,240	0,876	231,15
100%	44,071	24,234	0,876	231,17
Cos phi=1 no reactive power supply				
Rating power [%]	Active power [kW]	Reactive power [kVar]	Power factor [cos φ]	Voltage [V]
10%	5,141	0,512	0,010	230,28
20%	10,205	0,522	0,017	230,52
30%	15,240	0,490	0,027	229,76
40%	20,286	0,484	0,014	229,80
50%	25,331	0,628	0,021	230,02
60%	30,359	0,862	0,018	229,47
70%	35,365	0,345	0,016	229,71
80%	40,391	0,148	0,020	229,95
90%	45,375	-0,503	0,021	230,17
100%	49,779	1,291	0,049	230,38

**Assessment criterion:**


The power factor resulting in each of the measurement points between 20 % and 90 % of the nominal power is equal to or lower than 0,90 both in over excited and under excited operation,

The test method refer to clause CEI0-21 / EN 50438:2013, Annex D.3.4.2.1,


Generating plants must meet the reactive power requirement regardless of the number of feeding phases under normal steady-state operating conditions in the voltage tolerance band +10%U<sub>n</sub> and -15%U<sub>n</sub>.

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

Diagram



ASW30K-LT-G2



ASW50K-LT-G2

<b>4.7.2.2</b>	<b>Capabilities</b> <b>Q Response time</b>	<b>P</b>
----------------	---	----------


**Reaction time**

**Test result: ASW50K-LT-G2**


		<b>Time</b>	<b>Result</b>
1.	Reaction time Q=0 to Qmin (50% test)	6,2	P
2.	Reaction time Qmin to Qmax (50% test)	8,4	P
3.	Reaction time Qmax to Q=0 (50% test)	7,2	P
4.	Reaction time Q=0 to Qmin (100% test)	6,1	P
5.	Reaction time Qmin to Qmax (100% test)	8,6	P
6.	Reaction time Qmax to Q=0 (100% test)	9,1	P

**Test result:**

**Graph 50%Pn**



Graph 100%Pn



**Assessment criterion:**

DC source should be set to 50%(test1) and 100%(test2) output power micro-generator.

Starting with  $Q=0$  then  $Q_{min} \leq -0,4843 P_n$  to to  $Q_{max} \geq 0,4843 P_n$ , and then back to  $Q=0$  in doing so each point must be kept for at least 2 minute.

The total tolerance is  $\Delta Q \leq \pm 5,0\%$  of  $P_n$  or  $\Delta \cos\phi \leq \pm 0,01$

The maximum response time is 10s.


The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

4.7.2.2 Capabilities						P
4.7.2.3.3 Voltage related control modes (Q (U) controls)						
The validation of the Q (U) regulation according to VDE-AR-N 4105: 2018-05, 5.7.2.4 is divided into two partial tests, so that on the one hand the accuracy and on the other hand the dynamics of the Q (U) control is checked. For all inverter-coupled systems, only the inverter must be tested.						
Test result:ASW30K-LT-G2						
Qmin reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [% Un] Set point	P/Pn [%]	Vac [V] measured	Q [kVar] measured	Q [kVar] expected	$\Delta Q$ [% P <sub>E</sub> max]
< 20%	1,05Vn	16,29	241,81	-0,212	$\approx 0(<\pm 2,5\%P_n)$	-0,71
< 20%	1,07Vn	16,31	243,80	-0,215	$\approx 0(<\pm 2,5\%P_n)$	-0,72
< 20%-30%	1,07Vn	30,06	245,66	-6,933	0,5 Qmin	-1,31
40%	1,07Vn	39,86	245,70	-6,570	0,5 Qmin	-0,10
50%	1,07Vn	50,17	245,75	-6,567	0,5 Qmin	-0,09
60%	1,07Vn	59,71	245,69	-6,554	0,5 Qmin	-0,05
70%	1,07Vn	69,81	245,83	-6,543	0,5 Qmin	-0,01
80%	1,07Vn	79,87	245,69	-6,533	0,5 Qmin	0,02
90%	1,07Vn	89,94	245,84	-6,527	0,5 Qmin	0,04
100%	1,07Vn	99,80	245,79	-6,599	0,5 Qmin	-0,20
100%	1,08Vn	99,53	248,26	-13,085	Qmin	-0,02
100%-10%	1,08Vn	10,28	247,95	-12,983	Qmin	0,32
10%→ ≤5%	1,08Vn	3,99	247,92	-0,133	$\approx 0(<\pm 2,5\%P_n)$	-0,44
Qmax reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [% Un] Set point	P/Pn [%]	Vac [V] measured	Q [kVar] measured	Q [kVar] expected	$\Delta Q$ [% P <sub>E</sub> max]
< 20%	0,95Vn	15,33	218,32	-0,158	$\approx 0(<\pm 2,5\%P_n)$	-0,53
< 20%	0,93Vn	15,27	214,33	-0,152	$\approx 0(<\pm 2,5\%P_n)$	-0,51
< 20%-30%	0,93Vn	30,13	214,29	6,552	0,5 Qmax	0,04
40%	0,93Vn	40,14	214,36	6,563	0,5 Qmax	0,08
50%	0,93Vn	50,19	214,55	6,578	0,5 Qmax	0,13
60%	0,93Vn	60,27	214,41	6,588	0,5 Qmax	0,16
70%	0,93Vn	70,14	214,28	6,599	0,5 Qmax	0,20
80%	0,93Vn	80,25	214,27	6,489	0,5 Qmax	-0,17
90%	0,93Vn	90,17	214,25	6,585	0,5 Qmax	0,15
100%	0,93Vn	100,38	214,44	6,539	0,5 Qmax	0,00
100%	0,92Vn	100,83	212,11	13,070	Qmax	-0,03
100%-10%	0,92Vn	10,23	212,29	13,009	Qmax	-0,24
10%→ ≤5%	0,92Vn	3,29	212,10	-0,085	$\approx 0(<\pm 2,5\%P_n)$	-0,28


4.7.2.2 Capabilities						P
4.7.2.3.3 Voltage related control modes (Q (U) controls)						
The validation of the Q (U) regulation according to VDE-AR-N 4105: 2018-05, 5.7.2.4 is divided into two partial tests, so that on the one hand the accuracy and on the other hand the dynamics of the Q (U) control is checked. For all inverter-coupled systems, only the inverter must be tested.						
Test result:ASW50K-LT-G2						
Qmin reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [% Un] Set point	P/Pn [%]	Vac [V] measured	Q [kVar] measured	Q [kVar] expected	$\Delta Q$ [% P <sub>E</sub> max]
< 20%	1,05Vn	16,09	241,76	-0,235	$\approx 0(<\pm 2,5\%P_n)$	-0,47
< 20%	1,07Vn	16,10	243,75	-0,239	$\approx 0(<\pm 2,5\%P_n)$	-0,48
< 20%-30%	1,07Vn	30,67	245,54	-10,914	0,5 Qmin	-0,04
40%	1,07Vn	40,77	245,79	-10,907	0,5 Qmin	-0,02
50%	1,07Vn	50,87	245,64	-10,887	0,5 Qmin	0,02
60%	1,07Vn	60,67	245,69	-10,809	0,5 Qmin	0,17
70%	1,07Vn	70,62	245,74	-10,961	0,5 Qmin	-0,13
80%	1,07Vn	80,53	245,62	-10,905	0,5 Qmin	-0,02
90%	1,07Vn	90,95	245,77	-10,929	0,5 Qmin	-0,07
100%	1,07Vn	100,14	245,70	-10,833	0,5 Qmin	0,12
100%	1,08Vn	100,10	247,96	-21,765	Qmin	0,05
100%-10%	1,08Vn	10,66	247,72	-21,836	Qmin	-0,09
10%→ ≤5%	1,08Vn	3,69	248,16	-0,157	$\approx 0(<\pm 2,5\%P_n)$	-0,31
Qmin reactive power in accordance to standard characteristic curve Q=f(V)						
P/Pn	Vac [% Un] Set point	P/Pn [%]	Vac [V] measured	Q [kVar] measured	Q [kVar] expected	$\Delta Q$ [% P <sub>E</sub> max]
< 20%	0.95Vn	15,74	218,21	-0,150	$\approx 0(<\pm 2,5\%P_n)$	-0,30
< 20%	0,93Vn	15,70	214,20	-0,151	$\approx 0(<\pm 2,5\%P_n)$	-0,30
< 20%-30%	0,93Vn	30,53	214,37	10,892	0,5 Qmax	-0,01
40%	0,93Vn	40,41	214,25	10,925	0,5 Qmax	0,06
50%	0,93Vn	50,54	214,35	10,869	0,5 Qmax	-0,05
60%	0,93Vn	60,81	214,37	10,903	0,5 Qmax	0,02
70%	0,93Vn	71,06	214,28	10,753	0,5 Qmax	-0,28
80%	0,93Vn	80,58	214,30	10,978	0,5 Qmax	0,17
90%	0,93Vn	90,64	214,33	10,978	0,5 Qmax	0,17
100%	0,93Vn	100,20	214,35	10,914	0,5 Qmax	0,04
100%	0,92Vn	99,97	212,28	21,642	Qmax	-0,30
100%-10%	0,92Vn	10,78	212,07	21,892	Qmax	0,20
10%→ ≤5%	0,92Vn	3,15	212,05	-0,100	$\approx 0(<\pm 2,5\%P_n)$	-0,20



### Graph of ASW30K-LT-G2



### Graph of ASW50K-LT-G2



### Test:

The verification of the accuracy of the Q (U) control of the reactive power-voltage characteristic  $U_n$  shown in VDE-AR-N 4105: 2018-11, 5.7.2.4, Figure 7 is effected by a slow variation of the line voltage  $U_n$  in the range 90%  $U_n$  to 110%  $U_n$ . Depending on the type of EZE (single- or three-phase), the voltage changes must be carried out simultaneously or symmetrically on all phases.

- a) In order to check the stationary accuracy, the permissible voltage range shall be passed through within steps, with a step size of 1%  $U_n$ , but not greater than 2%  $U_n$ .
1. Pass the voltage range from 100%  $U_n$  down to the under voltage range to 90%  $U_n$ .
  2. Pass the voltage range from 90%  $U_n$  up to the over voltage range to 110%  $U_n$ .
  3. Pass the voltage range from 110%  $U_n$  down to the Nominal Voltage  $U_n$ .

The procedure is analogous to Figure 3 in Section 5.4.3.2.





Bild 7 – Standard-Q(U)-Kennlinie



**Bild 3 – Anforderungen an Erzeugungseinheiten bezüglich der Blindleistungsbereitstellung an den Generatorklemmen**  
( $\sum S_{E\max} > 4,6 \text{ kVA}$ )

The voltages are to be set with a maximum deviation of 0.25%  $U_n$ .

### Assessment criterion:

In order to pass the Q (U) accuracy test, the measured stationary value pairs  $U_{PGU}$  and  $Q_{PGU}$ , under taking account to the correct sign in the consumer metering system, must be within VDE-AR-N 4105: 2018-11, in 5.7.2.4, Figure 7 Q (U) shown characteristic. The stationary value pairs  $U_{PGU}$  and  $Q_{PGU}$  are determined by averaging over 30 seconds at the end of the respective measuring section analogously to Chapter 5.4.3.2. The permissible deviations are with the maximum measuring error of the voltage of 1%  $U_n$  stated in VDE-AR-N 4105: 2018-11 and a setting accuracy of 4%  $P_{EMax}$  at


$$Q_{EZE,tot} = \pm(0.01 \cdot U_{N,Y} \cdot k_{QU} + 0.04 \cdot P_{EMax}) = \pm 0,25 \cdot P_{EMax} \cdot (\sin(\arccos(\varphi_{min})) + 0.16).$$

### Note:


The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

Test of the dynamics of the Q (U) regulation			P
<b>Test result: ASW50K-LT-G2</b>			
Voltage jump Vac [% U <sub>n</sub> ]	Q [kVar] measured	Q [%Q <sub>max</sub> ] measured	T=3τ <sub>measured</sub>
100 to 108	-21,737	99,76	7,0 s
	-21,743	99,78	4,8 s
	-21,734	99,74	6,6 s
100 to 92	21,846	100,26	5,6 s
	21,795	100,02	6,6 s
	21,796	100,03	6,8 s
<p>Note:</p> <p>The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.</p>			


**Graph of 100%U<sub>n</sub> to 108% U<sub>n</sub>: Test 1**




**Graph of 100%U<sub>n</sub> to 108% U<sub>n</sub>: Test 2**




**Graph of 100%U<sub>n</sub> to 108% U<sub>n</sub>: Test 3**




**Graph of 100%U<sub>n</sub> to 92% U<sub>n</sub>: Test 1**



Graph of 100%U<sub>n</sub> to 92% U<sub>n</sub>: Test 2




Graph of 100%U<sub>n</sub> to 92% U<sub>n</sub>: Test 3




4.7.2.2 Capabilities										P
4.7.2.3.4 Power related Control mode (cos $\phi$ (P) curve)										
<b>Test result: ASW30K-LT-G2</b>										
<b>Test a):</b>										
Pn/P [%]	10	20	30	40	50	60	70	80	90	100
30 s mean value	20% to 100% P <sub>E<sub>max</sub></sub>									
U [V]:	N/A	228,17	228.34	228.51	228.67	228.83	228.97	229.14	229.28	229.38
P <sub>E30</sub> [kW]:	N/A	5,97	9.04	12.10	15.03	17.92	20.93	23.81	26.75	27.63
P <sub>E30</sub> of P <sub>n</sub> [%]:	N/A	19,91	30.13	40.33	50.09	59.72	69.76	79.37	89.18	92.10
Q <sub>E30</sub> [kVar]:	N/A	-0,09	-0.02	0.06	-0.42	-3.24	-5.62	-8.36	-10.78	-11.93
COS $\phi$ <sub>E30</sub> :	N/A	1,000	1.000	1.000	1.000	0.984	0.966	0.944	0.928	0.918
COS $\phi$ <sub>setpoint</sub> of P <sub>E30</sub> :	N/A	1,000	1,000	1,000	1,000	0,980	0,960	0,940	0,920	0,920
<b>Limit cos <math>\phi</math><sub>E30</sub>:</b>	<b>COS <math>\phi</math><sub>setpoint</sub> <math>\pm</math> 0,01</b>									
<b>Test b):</b>										
Pn/P [%]	20			50			100			
30 s mean value	20% to 50% to 100% P <sub>n</sub>									
U [V]:	228,16			228,72			229.35			
P <sub>E30</sub> [kW]:	5,958			14,996			27.621			
P <sub>E30</sub> of P <sub>n</sub> [%]:	19,86			49,99			92.07			
Q <sub>E30</sub> [kVar]:	-0,113			-0,407			-12.032			
COS $\phi$ <sub>E30</sub> :	1,000			0,999			0.917			
COS $\phi$ <sub>setpoint</sub> of P <sub>E30</sub> :	1,00			1,00			0.92			
T <sub>0</sub> [s]:	1,0 s					5,4s				
Pn/P [%]	100			50			20			
30 s mean value	100% to 50% to 20% P <sub>n</sub>									
U [V]:	229,33			228,68			228.16			
P <sub>E30</sub> [kW]:	27,688			14,98			5.958			
P <sub>E30</sub> [%]:	92,29			49,94			19.86			
Q <sub>E30</sub> [kVar]:	-11,996			-0,29			-0.113			
COS $\phi$ <sub>E30</sub> :	0,917			1,000			1.000			
COS $\phi$ <sub>setpoint</sub> of P <sub>E30</sub> :	0,92			1,00			1.00			
T <sub>0</sub> [s]:	5,8 s					1,0 s				
<b>Limit T<sub>0</sub> [s]:</b>	<b>10 s</b>									
<b>Limit cos <math>\phi</math><sub>E30</sub>:</b>	<b>COS <math>\phi</math><sub>setpoint</sub> <math>\pm</math> 0,02</b>									

**Test result:**

**Graph of  $\cos \phi(P)$ : Test a)**



**Graph of setting ( $T_0$ ) time: Test b): 100% to 50% to 20% to 50% to 100%Pn**







Test result: ASW50K-LT-G2										
Test a):										
Pn/P [%]	10	20	30	40	50	60	70	80	90	100
30 s mean value	20% to 100% P <sub>Emax</sub>									
U [V]:	N/A	229,53	229.75	229.97	230.17	230.37	230.58	230.81	231.04	231.12
P <sub>E30</sub> [kW]:	N/A	10,20	15.24	20.29	25.34	30.30	35.13	40.44	45.43	46.41
P <sub>E30</sub> of P <sub>n</sub> [%]:	N/A	20,40	30.49	40.59	50.67	60.61	70.26	80.87	90.86	92.83
Q <sub>E30</sub> [kVar]:	N/A	0,54	0.51	0.51	-1.04	-6.36	-10.67	-13.79	-18.15	-19.01
cos φ <sub>E30</sub> :	N/A	0,999	0.999	1.000	0.998	0.979	0.957	0.946	0.929	0.925
cos φ <sub>setpoint</sub> of P <sub>E30</sub> :	N/A	1,00	1.00	1.00	1.00	0.98	0.96	0.94	0.92	0.92
Limit cos φ <sub>E30</sub> :	cos φ <sub>setpoint</sub> ± 0,01									
Test b):										
Pn/P [%]	20			50			100			
30 s mean value	20% to 50% to 100% P <sub>n</sub>									
U [V]:	229,54			230,18			231.07			
P <sub>E30</sub> [kW]:	10,203			25,337			46.503			
P <sub>E30</sub> of P <sub>n</sub> [%]:	20,41			50,67			93,01			
Q <sub>E30</sub> [kVar]:	0,540			-1,305			-19.093			
cos φ <sub>E30</sub> :	0,999			0,998			0.925			
cos φ <sub>setpoint</sub> of P <sub>E30</sub> :	1,00			1,00			0.92			
T <sub>0</sub> [s]:	1,0					3,2s				
Pn/P [%]	100			50			20			
30 s mean value	100% to 50% to 20% P <sub>n</sub>									
U [V]:	231,13			230,26			229.54			
P <sub>E30</sub> [kW]:	46,485			25,34			10.203			
P <sub>E30</sub> [%]:	92,97			50,68			20,41			
Q <sub>E30</sub> [kVar]:	-19,092			-1,23			0.540			
cos φ <sub>E30</sub> :	0,925			0,998			0.999			
cos φ <sub>setpoint</sub> of P <sub>E30</sub> :	0,92			1,00			1.00			
T <sub>0</sub> [s]:	1,0					5,0 s				
Limit T <sub>0</sub> [s]:	10 s									
Limit cos φ <sub>E30</sub> :	cos φ <sub>setpoint</sub> ± 0,02									

**Test result:**

**Graph of  $\cos \phi(P)$ : Test a)**



**Graph of setting ( $T_0$ ) time: Test b): 100% to 50% to 20% to 50% to 100%Pn**




**Test:**

Test 1: Using the standard characteristic curve increases the active power from 20%  $P_n$  in increments of 10%  $P_n$  to  $P_{E_{max}}$ , The test is carried out in reverse.

Test 2: Using the standard characteristic curve increases the active power from 20%  $P_{E_{max}}$  to 50%  $P_{E_{max}}$  and to  $P_{E_{max}}$ , The test is carried out in reverse, After the PGU has settled, the end value reached is determined as a 30 s mean value.

Characteristic curve  $\cos \varphi (P)$



\*) Depending on  $S_{A_{max}}$

**Assessment criterion:**

Test 1:  $\cos \varphi$  accuracy  $\cos \varphi (\pm 0,01)$

Test 2:  $\cos \varphi$  accuracy  $\cos \varphi (\pm 0,02)$

For the test to be passed, the  $\cos \varphi$  setpoint from the active power must be measured at the terminals of the PGU within a settling time of 10 s.


**Note:**

The test method refer to clause 5,3,6,4 of VDE V 0124-100:2012-07.

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

<b>4.7.3 Voltage related active power reduction (P(U) function)</b>		<b>P</b>
<b>Test result:</b>		
5-min mean value / P/ P <sub>n</sub> [%]	100% to 20%	
Settling time [s]:	300	
P <sub>E60</sub> [%]:	16,7%	
ΔP <sub>E60</sub> /P <sub>Setpoint</sub> [%]:	20 % or less of P <sub>E<sub>max</sub></sub>	
<b>Limit settling time:</b>	600s	
<p>Test:</p> <p>a) Set the voltage to 2% V<sub>n</sub> lower than the activation threshold stated by the manufacturer.</p> <p>b) Set the voltage to 112%V<sub>n</sub>, The inverter now has to reduce its output power to value lower than 20%P<sub>n</sub> within 5min.</p> <p>c) Set the voltage back to 2%V<sub>n</sub> lower than the activation threshold, Check that the active power will return to the value consistent with the power available from the primary source or simulated.</p>		
<p><b>Assessment criterion:</b></p> <p>for adjustable PGUs:</p> <ul style="list-style-type: none"> <li>- no network disconnection</li> <li>- the active power value does not exceed the setpoint of 20% P<sub>E<sub>max</sub></sub></li> <li>- the setting time determined is equal or less than 600s</li> </ul>		
<p><b>Note:</b></p> <p>The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.</p>		

Graph:



### EN 50549-1:2019: Power quality

Clause	Test requirement	Test procedure according standard	Result
4.8	EMC and power quality	--	<b>P</b>
	Harmonic current emission	EN 61000-3-2, EN 61000-3-12	<b>P</b>
	Harmonic current emission	EN 61000-4-7	<b>P</b>
	Switching operations	IEC 61400-21	<b>P</b>
	Voltage fluctuation and flicker	EN 61000-3-3, EN 61000-3-11	<b>P</b>
	Flicker and voltage fluctuations	IEC 61400-21	<b>P</b>
	DC injection	EN 50438, Annex D,3,10	<b>P</b>
	Immunity to voltage dips and short interruptions	G59/3-4:2018-05, clause 13.8.4.5	<b>P</b>
	Unbalance	BDEW TG3, Revision 25, clause 4.3.5	<b>P</b>

4.8 EMC and power quality Harmonic current emission (EN 61000-3-12)								P
Test result: ASW30K-LT-G2								
Watts [KW]				9,940	10,064	9,973		
Vrms [V]				232,51	232,72	231,71		
Arms [A]				42,760	43,249	43,043		
Frequency [Hz]				50,000	50,000	50,000		
THD50* (100% output power)				1,102	1,119	1,170		
Harmonic order n	Current Magnitude [A] at 100% rated output power			% of Fundamental			Phase	Harmonic Current Limits [%]
	L1	L2	L3	L1	L2	L3		
1st	42,756	43,244	43,038	--	--	--	Three Phase	--
2nd	0,015	0,014	0,019	0,035	0,032	0,044	Three Phase	8,000
3rd	0,151	0,081	0,070	0,353	0,187	0,163	Three Phase	21,600
4th	0,138	0,125	0,138	0,323	0,289	0,321	Three Phase	4,000
5th	0,193	0,236	0,189	0,451	0,546	0,439	Three Phase	10,700
6th	0,016	0,013	0,021	0,037	0,030	0,049	Three Phase	2,667
7th	0,098	0,117	0,100	0,229	0,271	0,232	Three Phase	7,200
8th	0,035	0,029	0,044	0,082	0,067	0,102	Three Phase	2,000
9th	0,066	0,032	0,064	0,154	0,074	0,149	Three Phase	3,800
10th	0,023	0,024	0,030	0,054	0,055	0,070	Three Phase	1,600
11th	0,020	0,017	0,018	0,047	0,039	0,042	Three Phase	3,100
12th	0,009	0,009	0,011	0,021	0,021	0,026	Three Phase	1,333
13th	0,039	0,030	0,032	0,091	0,069	0,074	Three Phase	2,000
14th	0,026	0,018	0,026	0,061	0,042	0,060	Three Phase	N/A
15th	0,034	0,018	0,041	0,080	0,042	0,095	Three Phase	N/A
16th	0,018	0,023	0,028	0,042	0,053	0,065	Three Phase	N/A
17th	0,146	0,146	0,175	0,341	0,338	0,407	Three Phase	N/A
18th	0,008	0,009	0,013	0,019	0,021	0,030	Three Phase	N/A
19th	0,151	0,169	0,184	0,353	0,391	0,428	Three Phase	N/A
20th	0,021	0,015	0,021	0,049	0,035	0,049	Three Phase	N/A
21th	0,030	0,010	0,039	0,070	0,023	0,091	Three Phase	N/A
22th	0,018	0,024	0,027	0,042	0,055	0,063	Three Phase	N/A
23th	0,119	0,113	0,141	0,278	0,261	0,328	Three Phase	N/A
24th	0,008	0,009	0,012	0,019	0,021	0,028	Three Phase	N/A
25th	0,133	0,153	0,160	0,311	0,354	0,372	Three Phase	N/A
26th	0,021	0,016	0,020	0,049	0,037	0,046	Three Phase	N/A
27th	0,024	0,012	0,031	0,056	0,028	0,072	Three Phase	N/A
28th	0,017	0,025	0,026	0,040	0,058	0,060	Three Phase	N/A
29th	0,112	0,101	0,125	0,262	0,234	0,290	Three Phase	N/A
30th	0,007	0,008	0,011	0,016	0,018	0,026	Three Phase	N/A
31th	0,108	0,130	0,130	0,253	0,301	0,302	Three Phase	N/A
32th	0,020	0,017	0,020	0,047	0,039	0,046	Three Phase	N/A
33th	0,021	0,011	0,027	0,049	0,025	0,063	Three Phase	N/A
34th	0,022	0,032	0,028	0,051	0,074	0,065	Three Phase	N/A
35th	0,093	0,081	0,101	0,218	0,187	0,235	Three Phase	N/A
36th	0,007	0,009	0,010	0,016	0,021	0,023	Three Phase	N/A
37th	0,083	0,102	0,097	0,194	0,236	0,225	Three Phase	N/A
38th	0,020	0,019	0,019	0,047	0,044	0,044	Three Phase	N/A
39th	0,019	0,015	0,024	0,044	0,035	0,056	Three Phase	N/A
40th	0,038	0,054	0,039	0,089	0,125	0,091	Three Phase	N/A

4.8 EMC and power quality Harmonic current emission (EN 61000-3-12)								P
Test result: ASW33K-LT-G2								
Watts [KW]				10,952	11,087	10,982		
Vrms [V]				232,72	232,96	231,87		
Arms [A]				47,069	47,599	47,368		
Frequency [Hz]				50,000	50,000	50,000		
THD50* (100% output power)				0,982	0,997	1,031		
Harmonic order n	Current Magnitude [A] at 100% rated output power			% of Fundamental			Phase	Harmonic Current Limits [%]
	L1	L2	L3	L1	L2	L3		
1st	47,066	47,594	47,364	--	--	--	Three Phase	--
2nd	0,015	0,018	0,021	0,032	0,038	0,044	Three Phase	8,000
3rd	0,171	0,092	0,077	0,363	0,193	0,163	Three Phase	21,600
4th	0,137	0,125	0,140	0,291	0,263	0,296	Three Phase	4,000
5th	0,193	0,241	0,191	0,410	0,506	0,403	Three Phase	10,700
6th	0,019	0,014	0,023	0,040	0,029	0,049	Three Phase	2,667
7th	0,094	0,113	0,097	0,200	0,237	0,205	Three Phase	7,200
8th	0,034	0,029	0,043	0,072	0,061	0,091	Three Phase	2,000
9th	0,061	0,028	0,060	0,130	0,059	0,127	Three Phase	3,800
10th	0,023	0,025	0,030	0,049	0,053	0,063	Three Phase	1,600
11th	0,018	0,016	0,016	0,038	0,034	0,034	Three Phase	3,100
12th	0,009	0,009	0,012	0,019	0,019	0,025	Three Phase	1,333
13th	0,036	0,027	0,024	0,076	0,057	0,051	Three Phase	2,000
14th	0,025	0,018	0,027	0,053	0,038	0,057	Three Phase	N/A
15th	0,032	0,018	0,036	0,068	0,038	0,076	Three Phase	N/A
16th	0,018	0,024	0,028	0,038	0,050	0,059	Three Phase	N/A
17th	0,137	0,146	0,165	0,291	0,307	0,348	Three Phase	N/A
18th	0,008	0,009	0,013	0,017	0,019	0,027	Three Phase	N/A
19th	0,146	0,159	0,176	0,310	0,334	0,372	Three Phase	N/A
20th	0,020	0,014	0,021	0,042	0,029	0,044	Three Phase	N/A
21th	0,028	0,009	0,036	0,059	0,019	0,076	Three Phase	N/A
22th	0,016	0,023	0,026	0,034	0,048	0,055	Three Phase	N/A
23th	0,108	0,105	0,131	0,229	0,221	0,277	Three Phase	N/A
24th	0,008	0,008	0,012	0,017	0,017	0,025	Three Phase	N/A
25th	0,122	0,140	0,147	0,259	0,294	0,310	Three Phase	N/A
26th	0,021	0,015	0,020	0,045	0,032	0,042	Three Phase	N/A
27th	0,023	0,010	0,030	0,049	0,021	0,063	Three Phase	N/A
28th	0,017	0,025	0,025	0,036	0,053	0,053	Three Phase	N/A
29th	0,104	0,095	0,119	0,221	0,200	0,251	Three Phase	N/A
30th	0,007	0,008	0,011	0,015	0,017	0,023	Three Phase	N/A
31th	0,104	0,124	0,126	0,221	0,261	0,266	Three Phase	N/A
32th	0,020	0,017	0,019	0,042	0,036	0,040	Three Phase	N/A
33th	0,022	0,011	0,026	0,047	0,023	0,055	Three Phase	N/A
34th	0,022	0,031	0,026	0,047	0,065	0,055	Three Phase	N/A
35th	0,090	0,080	0,101	0,191	0,168	0,213	Three Phase	N/A
36th	0,007	0,010	0,010	0,015	0,021	0,021	Three Phase	N/A
37th	0,082	0,101	0,098	0,174	0,212	0,207	Three Phase	N/A
38th	0,020	0,017	0,019	0,042	0,036	0,040	Three Phase	N/A
39th	0,020	0,014	0,025	0,042	0,029	0,053	Three Phase	N/A
40th	0,039	0,055	0,040	0,083	0,116	0,084	Three Phase	N/A



4.8 EMC and power quality Harmonic current emission (EN 61000-3-12)								P
Test result: ASW36K-LT-G2								
Watts [KW]				11,963	12,103	11,989		
Vrms [V]				232,94	233,18	232,02		
Arms [A]				51,364	51,913	51,674		
Frequency [Hz]				50,000	50,000	50,000		
THD50* (100% output power)				0,888	0,908	0,931		
Harmonic order n	Current Magnitude [A] at 100% rated output power			% of Fundamental			Phase	Harmonic Current Limits [%]
	L1	L2	L3	L1	L2	L3		
1st	51,360	51,909	51,670	--	--	--	Three Phase	--
2nd	0,016	0,021	0,024	0,031	0,040	0,046	Three Phase	8,000
3rd	0,168	0,078	0,088	0,327	0,150	0,170	Three Phase	21,600
4th	0,139	0,128	0,142	0,271	0,247	0,275	Three Phase	4,000
5th	0,208	0,261	0,207	0,405	0,503	0,401	Three Phase	10,700
6th	0,017	0,014	0,023	0,033	0,027	0,045	Three Phase	2,667
7th	0,081	0,099	0,085	0,158	0,191	0,165	Three Phase	7,200
8th	0,034	0,029	0,045	0,066	0,056	0,087	Three Phase	2,000
9th	0,054	0,025	0,053	0,105	0,048	0,103	Three Phase	3,800
10th	0,024	0,024	0,030	0,047	0,046	0,058	Three Phase	1,600
11th	0,020	0,018	0,019	0,039	0,035	0,037	Three Phase	3,100
12th	0,010	0,009	0,013	0,019	0,017	0,025	Three Phase	1,333
13th	0,035	0,027	0,027	0,068	0,052	0,052	Three Phase	2,000
14th	0,026	0,019	0,028	0,051	0,037	0,054	Three Phase	N/A
15th	0,031	0,021	0,033	0,060	0,040	0,064	Three Phase	N/A
16th	0,018	0,024	0,027	0,035	0,046	0,052	Three Phase	N/A
17th	0,131	0,143	0,154	0,255	0,275	0,298	Three Phase	N/A
18th	0,008	0,009	0,014	0,016	0,017	0,027	Three Phase	N/A
19th	0,146	0,154	0,173	0,284	0,297	0,335	Three Phase	N/A
20th	0,021	0,015	0,021	0,041	0,029	0,041	Three Phase	N/A
21th	0,025	0,009	0,032	0,049	0,017	0,062	Three Phase	N/A
22th	0,016	0,022	0,025	0,031	0,042	0,048	Three Phase	N/A
23th	0,102	0,099	0,123	0,199	0,191	0,238	Three Phase	N/A
24th	0,007	0,008	0,012	0,014	0,015	0,023	Three Phase	N/A
25th	0,113	0,131	0,138	0,220	0,252	0,267	Three Phase	N/A
26th	0,021	0,015	0,019	0,041	0,029	0,037	Three Phase	N/A
27th	0,022	0,009	0,029	0,043	0,017	0,056	Three Phase	N/A
28th	0,017	0,025	0,026	0,033	0,048	0,050	Three Phase	N/A
29th	0,097	0,090	0,112	0,189	0,173	0,217	Three Phase	N/A
30th	0,007	0,009	0,011	0,014	0,017	0,021	Three Phase	N/A
31th	0,100	0,119	0,120	0,195	0,229	0,232	Three Phase	N/A
32th	0,021	0,017	0,019	0,041	0,033	0,037	Three Phase	N/A
33th	0,020	0,010	0,024	0,039	0,019	0,046	Three Phase	N/A
34th	0,022	0,031	0,027	0,043	0,060	0,052	Three Phase	N/A
35th	0,088	0,078	0,098	0,171	0,150	0,190	Three Phase	N/A
36th	0,007	0,009	0,010	0,014	0,017	0,019	Three Phase	N/A
37th	0,081	0,100	0,097	0,158	0,193	0,188	Three Phase	N/A
38th	0,021	0,019	0,019	0,041	0,037	0,037	Three Phase	N/A
39th	0,020	0,015	0,024	0,039	0,029	0,046	Three Phase	N/A
40th	0,040	0,056	0,041	0,078	0,108	0,079	Three Phase	N/A

4.8 EMC and power quality Harmonic current emission (EN 61000-3-12)								P
Test result: ASW40K-LT-G2								
Watts [KW]				13,304	13,462	13,334		
Vrms [V]				233,13	233,45	232,34		
Arms [A]				57,074	57,675	57,395		
Frequency [Hz]				50,000	50,000	50,000		
THD50* (100% output power)				0,794	0,817	0,825		
Harmonic order n	Current Magnitude [A] at 100% rated output power			% of Fundamental			Phase	Harmonic Current Limits [%]
	L1	L2	L3	L1	L2	L3		
1st	57,070	57,670	57,390	--	--	--	Three Phase	--
2nd	0,019	0,022	0,025	0,033	0,038	0,044	Three Phase	8,000
3rd	0,161	0,078	0,083	0,282	0,135	0,145	Three Phase	21,600
4th	0,146	0,133	0,149	0,256	0,231	0,260	Three Phase	4,000
5th	0,225	0,278	0,224	0,394	0,482	0,390	Three Phase	10,700
6th	0,018	0,015	0,023	0,032	0,026	0,040	Three Phase	2,667
7th	0,068	0,090	0,076	0,119	0,156	0,132	Three Phase	7,200
8th	0,036	0,029	0,044	0,063	0,050	0,077	Three Phase	2,000
9th	0,044	0,021	0,047	0,077	0,036	0,082	Three Phase	3,800
10th	0,024	0,025	0,031	0,042	0,043	0,054	Three Phase	1,600
11th	0,020	0,022	0,018	0,035	0,038	0,031	Three Phase	3,100
12th	0,010	0,009	0,012	0,018	0,016	0,021	Three Phase	1,333
13th	0,026	0,025	0,022	0,046	0,043	0,038	Three Phase	2,000
14th	0,025	0,021	0,028	0,044	0,036	0,049	Three Phase	N/A
15th	0,032	0,022	0,032	0,056	0,038	0,056	Three Phase	N/A
16th	0,020	0,025	0,028	0,035	0,043	0,049	Three Phase	N/A
17th	0,126	0,138	0,143	0,221	0,239	0,249	Three Phase	N/A
18th	0,008	0,009	0,012	0,014	0,016	0,021	Three Phase	N/A
19th	0,141	0,144	0,165	0,247	0,250	0,288	Three Phase	N/A
20th	0,022	0,015	0,020	0,039	0,026	0,035	Three Phase	N/A
21th	0,022	0,011	0,028	0,039	0,019	0,049	Three Phase	N/A
22th	0,017	0,024	0,026	0,030	0,042	0,045	Three Phase	N/A
23th	0,099	0,097	0,118	0,173	0,168	0,206	Three Phase	N/A
24th	0,008	0,009	0,013	0,014	0,016	0,023	Three Phase	N/A
25th	0,107	0,124	0,130	0,187	0,215	0,227	Three Phase	N/A
26th	0,021	0,016	0,019	0,037	0,028	0,033	Three Phase	N/A
27th	0,021	0,008	0,028	0,037	0,014	0,049	Three Phase	N/A
28th	0,017	0,025	0,025	0,030	0,043	0,044	Three Phase	N/A
29th	0,092	0,084	0,106	0,161	0,146	0,185	Three Phase	N/A
30th	0,007	0,009	0,012	0,012	0,016	0,021	Three Phase	N/A
31th	0,095	0,114	0,114	0,166	0,198	0,199	Three Phase	N/A
32th	0,022	0,018	0,020	0,039	0,031	0,035	Three Phase	N/A
33th	0,019	0,010	0,024	0,033	0,017	0,042	Three Phase	N/A
34th	0,023	0,033	0,028	0,040	0,057	0,049	Three Phase	N/A
35th	0,086	0,076	0,095	0,151	0,132	0,166	Three Phase	N/A
36th	0,007	0,011	0,012	0,012	0,019	0,021	Three Phase	N/A
37th	0,081	0,099	0,095	0,142	0,172	0,166	Three Phase	N/A
38th	0,021	0,020	0,019	0,037	0,035	0,033	Three Phase	N/A
39th	0,020	0,015	0,023	0,035	0,026	0,040	Three Phase	N/A
40th	0,040	0,056	0,041	0,070	0,097	0,071	Three Phase	N/A

4.8 EMC and power quality Harmonic current emission (EN 61000-3-12)								P
Test result: ASW45K-LT-G2								
Watts [KW]				14,960	15,133	14,985		
Vrms [V]				233,47	233,77	232,58		
Arms [A]				64,093	64,750	64,437		
Frequency [Hz]				50,000	50,000	50,000		
THD50* (100% output power)				0,840	0,957	0,865		
Harmonic order n	Current Magnitude [A] at 100% rated output power			% of Fundamental			Phase	Harmonic Current Limits [%]
	L1	L2	L3	L1	L2	L3		
1st	64,026	64,673	64,357	--	--	--	Three Phase	--
2nd	0,219	0,286	0,223	0,342	0,442	0,347	Three Phase	8,000
3rd	0,165	0,173	0,147	0,258	0,267	0,228	Three Phase	21,600
4th	0,169	0,181	0,166	0,264	0,280	0,258	Three Phase	4,000
5th	0,279	0,327	0,266	0,436	0,506	0,413	Three Phase	10,700
6th	0,053	0,064	0,061	0,083	0,099	0,095	Three Phase	2,667
7th	0,053	0,083	0,061	0,083	0,128	0,095	Three Phase	7,200
8th	0,045	0,058	0,061	0,070	0,090	0,095	Three Phase	2,000
9th	0,039	0,043	0,046	0,061	0,066	0,071	Three Phase	3,800
10th	0,030	0,044	0,039	0,047	0,068	0,061	Three Phase	1,600
11th	0,039	0,050	0,033	0,061	0,077	0,051	Three Phase	3,100
12th	0,021	0,032	0,025	0,033	0,049	0,039	Three Phase	1,333
13th	0,027	0,038	0,031	0,042	0,059	0,048	Three Phase	2,000
14th	0,031	0,035	0,031	0,048	0,054	0,048	Three Phase	N/A
15th	0,032	0,032	0,031	0,050	0,049	0,048	Three Phase	N/A
16th	0,026	0,034	0,032	0,041	0,053	0,050	Three Phase	N/A
17th	0,119	0,128	0,129	0,186	0,198	0,200	Three Phase	N/A
18th	0,012	0,020	0,018	0,019	0,031	0,028	Three Phase	N/A
19th	0,137	0,139	0,157	0,214	0,215	0,244	Three Phase	N/A
20th	0,022	0,026	0,024	0,034	0,040	0,037	Three Phase	N/A
21th	0,018	0,021	0,025	0,028	0,032	0,039	Three Phase	N/A
22th	0,020	0,029	0,028	0,031	0,045	0,044	Three Phase	N/A
23th	0,099	0,096	0,110	0,155	0,148	0,171	Three Phase	N/A
24th	0,012	0,017	0,015	0,019	0,026	0,023	Three Phase	N/A
25th	0,107	0,122	0,128	0,167	0,189	0,199	Three Phase	N/A
26th	0,024	0,021	0,022	0,037	0,032	0,034	Three Phase	N/A
27th	0,019	0,017	0,027	0,030	0,026	0,042	Three Phase	N/A
28th	0,020	0,028	0,027	0,031	0,043	0,042	Three Phase	N/A
29th	0,092	0,081	0,102	0,144	0,125	0,158	Three Phase	N/A
30th	0,008	0,015	0,014	0,012	0,023	0,022	Three Phase	N/A
31th	0,092	0,111	0,110	0,144	0,172	0,171	Three Phase	N/A
32th	0,021	0,022	0,022	0,033	0,034	0,034	Three Phase	N/A
33th	0,018	0,015	0,025	0,028	0,023	0,039	Three Phase	N/A
34th	0,024	0,033	0,029	0,037	0,051	0,045	Three Phase	N/A
35th	0,087	0,076	0,092	0,136	0,118	0,143	Three Phase	N/A
36th	0,010	0,014	0,012	0,016	0,022	0,019	Three Phase	N/A
37th	0,082	0,100	0,096	0,128	0,155	0,149	Three Phase	N/A
38th	0,022	0,022	0,021	0,034	0,034	0,033	Three Phase	N/A
39th	0,019	0,018	0,024	0,030	0,028	0,037	Three Phase	N/A
40th	0,043	0,058	0,042	0,067	0,090	0,065	Three Phase	N/A

4.8 EMC and power quality Harmonic current emission (EN 61000-3-12)								P
Test result: ASW50K-LT-G2								
Watts [KW]				16,589	16,550	16,648		
Vrms [V]				230,30	230,38	230,38		
Arms [A]				72,057	71,864	72,287		
Frequency [Hz]				49,999	49,999	49,999		
THD50* (100% output power)				1,507	1,631	1,376		
Harmonic order n	Current Magnitude [A] at 100% rated output power			% of Fundamental			Phase	Harmonic Current Limits [%]
	L1	L2	L3	L1	L2	L3		
1st	72,032	71,838	72,266	--	--	--	Three Phase	--
2nd	0,097	0,046	0,108	0,135	0,064	0,149	Three Phase	8,000
3rd	0,397	0,646	0,303	0,551	0,899	0,419	Three Phase	21,600
4th	0,349	0,293	0,338	0,485	0,408	0,468	Three Phase	4,000
5th	0,477	0,489	0,406	0,662	0,681	0,562	Three Phase	10,700
6th	0,060	0,062	0,071	0,083	0,086	0,098	Three Phase	2,667
7th	0,151	0,147	0,139	0,210	0,205	0,192	Three Phase	7,200
8th	0,352	0,293	0,338	0,489	0,408	0,468	Three Phase	2,000
9th	0,078	0,081	0,091	0,108	0,113	0,126	Three Phase	3,800
10th	0,188	0,189	0,167	0,261	0,263	0,231	Three Phase	1,600
11th	0,098	0,101	0,089	0,136	0,141	0,123	Three Phase	3,100
12th	0,055	0,049	0,056	0,076	0,068	0,077	Three Phase	1,333
13th	0,070	0,058	0,057	0,097	0,081	0,079	Three Phase	2,000
14th	0,107	0,104	0,124	0,149	0,145	0,172	Three Phase	N/A
15th	0,073	0,058	0,053	0,101	0,081	0,073	Three Phase	N/A
16th	0,214	0,244	0,224	0,297	0,340	0,310	Three Phase	N/A
17th	0,297	0,281	0,276	0,412	0,391	0,382	Three Phase	N/A
18th	0,060	0,055	0,052	0,083	0,077	0,072	Three Phase	N/A
19th	0,135	0,156	0,142	0,187	0,217	0,196	Three Phase	N/A
20th	0,190	0,174	0,170	0,264	0,242	0,235	Three Phase	N/A
21th	0,057	0,057	0,057	0,079	0,079	0,079	Three Phase	N/A
22th	0,124	0,116	0,107	0,172	0,161	0,148	Three Phase	N/A
23th	0,088	0,078	0,080	0,122	0,109	0,111	Three Phase	N/A
24th	0,055	0,053	0,056	0,076	0,074	0,077	Three Phase	N/A
25th	0,240	0,236	0,225	0,333	0,329	0,311	Three Phase	N/A
26th	0,093	0,115	0,089	0,129	0,160	0,123	Three Phase	N/A
27th	0,051	0,055	0,059	0,071	0,077	0,082	Three Phase	N/A
28th	0,092	0,087	0,093	0,128	0,121	0,129	Three Phase	N/A
29th	0,090	0,106	0,075	0,125	0,148	0,104	Three Phase	N/A
30th	0,058	0,055	0,050	0,081	0,077	0,069	Three Phase	N/A
31th	0,186	0,197	0,185	0,258	0,274	0,256	Three Phase	N/A
32th	0,084	0,086	0,090	0,117	0,120	0,125	Three Phase	N/A
33th	0,060	0,057	0,055	0,083	0,079	0,076	Three Phase	N/A
34th	0,158	0,174	0,154	0,219	0,242	0,213	Three Phase	N/A
35th	0,168	0,145	0,148	0,233	0,202	0,205	Three Phase	N/A
36th	0,052	0,053	0,048	0,072	0,074	0,066	Three Phase	N/A
37th	0,089	0,071	0,087	0,124	0,099	0,120	Three Phase	N/A
38th	0,095	0,103	0,090	0,132	0,143	0,125	Three Phase	N/A
39th	0,052	0,051	0,050	0,072	0,071	0,069	Three Phase	N/A
40th	0,073	0,084	0,077	0,101	0,117	0,107	Three Phase	N/A

**Note:**The tests should be based on the limits of the EN 61000-3-12 for more than 16A.

4.8 EMC and power quality Harmonic current emission (EN 61000-4-7)											P
The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A, The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.											
<b>Test result: ASW30K-LT-G2</b>											
<b>Harmonics</b>											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1	4,460	10,557	20,942	31,224	41,584	51,647	61,195	72,077	81,729	91,644	101,431
2	0,147	0,156	0,174	0,177	0,173	0,169	0,168	0,167	0,194	0,181	0,189
3	0,384	0,126	0,594	0,504	0,531	0,581	0,407	0,435	0,488	0,417	0,424
4	0,102	0,111	0,058	0,105	0,103	0,127	0,142	0,175	0,222	0,174	0,184
5	0,299	0,330	0,353	0,382	0,469	0,469	0,490	0,532	0,527	0,521	0,522
6	0,060	0,048	0,071	0,049	0,040	0,036	0,041	0,059	0,084	0,047	0,042
7	0,083	0,161	0,140	0,151	0,134	0,212	0,193	0,186	0,213	0,233	0,237
8	0,046	0,050	0,067	0,048	0,055	0,036	0,041	0,053	0,068	0,056	0,059
9	0,087	0,113	0,111	0,098	0,118	0,167	0,103	0,085	0,092	0,110	0,108
10	0,042	0,043	0,027	0,041	0,035	0,028	0,033	0,201	0,169	0,048	0,049
11	0,114	0,086	0,108	0,098	0,091	0,061	0,068	0,088	0,086	0,178	0,138
12	0,039	0,030	0,034	0,033	0,032	0,026	0,029	0,238	0,206	0,033	0,031
13	0,180	0,180	0,152	0,068	0,140	0,097	0,084	0,096	0,102	0,169	0,140
14	0,037	0,034	0,041	0,029	0,041	0,033	0,033	0,035	0,044	0,045	0,047
15	0,079	0,044	0,095	0,102	0,024	0,134	0,094	0,073	0,087	0,091	0,114
16	0,024	0,026	0,024	0,030	0,028	0,025	0,029	0,036	0,044	0,047	0,050
17	0,485	0,395	0,248	0,414	0,413	0,311	0,195	0,198	0,214	0,238	0,278
18	0,026	0,022	0,029	0,041	0,027	0,022	0,025	0,023	0,028	0,025	0,028
19	0,453	0,514	0,381	0,491	0,292	0,285	0,189	0,179	0,192	0,222	0,270
20	0,031	0,022	0,039	0,037	0,020	0,026	0,026	0,029	0,037	0,038	0,040
21	0,111	0,078	0,155	0,049	0,067	0,059	0,059	0,059	0,075	0,077	0,081
22	0,024	0,028	0,035	0,020	0,017	0,028	0,029	0,034	0,042	0,048	0,051
23	0,358	0,318	0,322	0,257	0,163	0,182	0,143	0,150	0,167	0,190	0,207
24	0,025	0,023	0,024	0,018	0,019	0,020	0,020	0,021	0,026	0,023	0,024
25	0,392	0,404	0,273	0,206	0,172	0,168	0,135	0,136	0,159	0,189	0,206
26	0,034	0,025	0,034	0,021	0,017	0,026	0,026	0,031	0,038	0,040	0,040
27	0,091	0,102	0,110	0,083	0,073	0,016	0,031	0,047	0,060	0,068	0,069
28	0,031	0,027	0,034	0,018	0,014	0,029	0,029	0,034	0,043	0,048	0,052
29	0,308	0,290	0,266	0,189	0,173	0,099	0,106	0,117	0,133	0,151	0,168
30	0,020	0,021	0,022	0,019	0,017	0,020	0,017	0,020	0,026	0,021	0,022
31	0,336	0,302	0,314	0,223	0,188	0,104	0,103	0,111	0,135	0,160	0,178
32	0,025	0,030	0,027	0,019	0,019	0,024	0,026	0,031	0,039	0,038	0,040
33	0,050	0,062	0,039	0,038	0,044	0,039	0,030	0,037	0,054	0,054	0,064
34	0,028	0,032	0,027	0,024	0,021	0,030	0,030	0,034	0,041	0,045	0,050
35	0,239	0,258	0,199	0,154	0,152	0,109	0,114	0,113	0,123	0,144	0,158
36	0,025	0,021	0,020	0,019	0,023	0,019	0,022	0,026	0,033	0,021	0,024
37	0,250	0,211	0,210	0,112	0,121	0,077	0,081	0,091	0,115	0,126	0,142
38	0,032	0,038	0,029	0,025	0,027	0,030	0,031	0,034	0,040	0,038	0,044
39	0,137	0,174	0,127	0,115	0,121	0,121	0,122	0,120	0,119	0,142	0,141
40	0,033	0,039	0,032	0,020	0,031	0,026	0,032	0,036	0,044	0,047	0,046

4.8 EMC and power quality Harmonic current emission (EN 61000-4-7)											P
The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A, The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.											
<b>Test result: ASW30K-LT-G2</b>											
<b>Interharmonics</b>											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
75	0,091	0,099	0,172	0,234	0,301	0,354	0,413	0,548	0,754	0,657	0,714
125	0,089	0,098	0,169	0,239	0,291	0,352	0,425	0,543	0,651	0,646	0,708
175	0,041	0,042	0,048	0,068	0,073	0,075	0,084	0,110	0,152	0,133	0,127
225	0,039	0,037	0,047	0,055	0,056	0,063	0,065	0,098	0,122	0,091	0,092
275	0,057	0,049	0,055	0,053	0,047	0,044	0,034	0,051	0,059	0,049	0,048
325	0,101	0,068	0,109	0,096	0,060	0,049	0,050	0,057	0,063	0,053	0,055
375	0,062	0,046	0,063	0,058	0,056	0,044	0,032	0,039	0,044	0,035	0,035
425	0,088	0,066	0,097	0,089	0,063	0,048	0,047	0,051	0,050	0,047	0,046
475	0,047	0,032	0,034	0,030	0,031	0,034	0,032	0,034	0,038	0,035	0,031
525	0,029	0,025	0,032	0,023	0,026	0,027	0,026	0,032	0,039	0,032	0,033
575	0,049	0,043	0,047	0,032	0,041	0,037	0,029	0,066	0,085	0,034	0,033
625	0,101	0,073	0,083	0,079	0,097	0,067	0,055	0,052	0,056	0,114	0,122
675	0,051	0,042	0,046	0,037	0,045	0,040	0,031	0,073	0,095	0,040	0,038
725	0,102	0,084	0,087	0,071	0,089	0,068	0,058	0,051	0,050	0,110	0,120
775	0,047	0,038	0,030	0,027	0,026	0,032	0,034	0,026	0,029	0,026	0,028
825	0,031	0,028	0,026	0,022	0,021	0,027	0,031	0,024	0,026	0,022	0,027
875	0,066	0,063	0,054	0,065	0,047	0,066	0,048	0,042	0,040	0,038	0,044
925	0,078	0,065	0,073	0,063	0,055	0,054	0,046	0,037	0,037	0,040	0,043
975	0,070	0,059	0,074	0,066	0,041	0,067	0,052	0,047	0,044	0,047	0,050
1025	0,085	0,077	0,075	0,075	0,053	0,059	0,050	0,042	0,043	0,041	0,044
1075	0,046	0,029	0,032	0,026	0,023	0,027	0,031	0,024	0,025	0,029	0,029
1125	0,029	0,024	0,021	0,019	0,019	0,020	0,027	0,023	0,026	0,024	0,022
1175	0,085	0,049	0,055	0,040	0,037	0,058	0,046	0,042	0,045	0,048	0,047
1225	0,078	0,065	0,066	0,052	0,036	0,051	0,046	0,038	0,039	0,046	0,042
1275	0,077	0,049	0,051	0,042	0,045	0,056	0,051	0,046	0,047	0,056	0,053
1325	0,083	0,074	0,072	0,055	0,040	0,055	0,051	0,044	0,046	0,047	0,045
1375	0,078	0,062	0,026	0,022	0,023	0,024	0,028	0,030	0,029	0,037	0,030
1425	0,026	0,021	0,018	0,020	0,018	0,018	0,024	0,023	0,028	0,023	0,022
1475	0,074	0,082	0,050	0,046	0,051	0,044	0,047	0,048	0,054	0,053	0,050
1525	0,066	0,056	0,057	0,050	0,045	0,047	0,047	0,041	0,042	0,042	0,047
1575	0,094	0,060	0,055	0,056	0,060	0,046	0,050	0,056	0,068	0,058	0,058
1625	0,070	0,055	0,072	0,062	0,050	0,047	0,047	0,043	0,045	0,045	0,048
1675	0,069	0,112	0,148	0,130	0,145	0,123	0,119	0,084	0,131	0,095	0,094
1725	0,024	0,032	0,025	0,032	0,026	0,031	0,028	0,025	0,034	0,025	0,032
1775	0,295	0,477	0,431	0,439	0,445	0,442	0,438	0,369	0,315	0,402	0,429
1825	0,055	0,057	0,055	0,054	0,054	0,048	0,052	0,049	0,050	0,049	0,053
1875	0,164	0,078	0,052	0,050	0,050	0,045	0,051	0,151	0,104	0,057	0,059
1925	0,059	0,049	0,052	0,050	0,051	0,042	0,047	0,042	0,056	0,048	0,049
1975	0,630	0,792	0,573	0,560	0,564	0,585	0,596	0,523	0,470	0,616	0,627

4.8 EMC and power quality Harmonic current emission (EN 61000-4-7)											P
The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A, The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.											
<b>Test result: ASW30K-LT-G2</b>											
<b>Higher Frequencies</b>											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2,1	0,671	0,750	0,530	0,533	0,513	0,518	0,523	0,519	0,465	0,596	0,589
2,3	0,415	0,571	0,516	0,514	0,516	0,505	0,488	0,433	0,428	0,476	0,490
2,5	0,178	0,159	0,098	0,084	0,077	0,084	0,092	0,119	0,119	0,117	0,124
2,7	0,194	0,174	0,138	0,099	0,100	0,091	0,093	0,092	0,103	0,118	0,124
2,9	0,159	0,142	0,092	0,075	0,065	0,062	0,063	0,063	0,074	0,083	0,091
3,1	0,148	0,130	0,086	0,085	0,062	0,062	0,066	0,069	0,074	0,082	0,088
3,3	0,143	0,127	0,062	0,065	0,056	0,063	0,072	0,075	0,081	0,091	0,099
3,5	0,105	0,082	0,046	0,061	0,074	0,084	0,089	0,091	0,090	0,096	0,098
3,7	0,081	0,074	0,044	0,048	0,044	0,046	0,049	0,047	0,050	0,051	0,053
3,9	0,073	0,068	0,053	0,054	0,046	0,045	0,043	0,041	0,049	0,042	0,043
4,1	0,063	0,050	0,053	0,049	0,041	0,040	0,037	0,037	0,039	0,036	0,038
4,3	0,056	0,049	0,051	0,047	0,039	0,038	0,036	0,036	0,040	0,038	0,038
4,5	0,040	0,034	0,040	0,040	0,035	0,036	0,036	0,036	0,036	0,034	0,034
4,7	0,036	0,030	0,033	0,032	0,031	0,031	0,031	0,032	0,031	0,030	0,032
4,9	0,032	0,021	0,026	0,026	0,031	0,032	0,030	0,027	0,027	0,026	0,026
5,1	0,028	0,018	0,024	0,026	0,024	0,026	0,027	0,027	0,027	0,025	0,026
5,3	0,022	0,016	0,023	0,022	0,020	0,023	0,024	0,024	0,024	0,023	0,023
5,5	0,022	0,015	0,021	0,021	0,019	0,022	0,023	0,023	0,023	0,021	0,021
5,7	0,018	0,015	0,020	0,021	0,018	0,022	0,021	0,021	0,022	0,021	0,021
5,9	0,016	0,015	0,018	0,019	0,018	0,020	0,021	0,021	0,021	0,020	0,020
6,1	0,018	0,016	0,018	0,019	0,018	0,019	0,021	0,021	0,021	0,020	0,021
6,3	0,017	0,016	0,017	0,019	0,017	0,020	0,020	0,022	0,021	0,021	0,022
6,5	0,018	0,018	0,016	0,018	0,016	0,020	0,019	0,020	0,020	0,020	0,021
6,7	0,021	0,017	0,018	0,018	0,016	0,018	0,018	0,019	0,018	0,019	0,019
6,9	0,022	0,018	0,023	0,019	0,017	0,020	0,018	0,019	0,019	0,020	0,020
7,1	0,024	0,029	0,025	0,030	0,031	0,031	0,032	0,030	0,030	0,034	0,034
7,3	0,017	0,016	0,016	0,017	0,016	0,018	0,018	0,021	0,020	0,020	0,021
7,5	0,022	0,023	0,027	0,028	0,026	0,026	0,027	0,025	0,024	0,027	0,029
7,7	0,016	0,016	0,018	0,017	0,015	0,016	0,018	0,019	0,019	0,018	0,019
7,9	0,016	0,016	0,017	0,017	0,016	0,018	0,018	0,019	0,018	0,018	0,019
8,1	0,016	0,016	0,016	0,016	0,016	0,018	0,017	0,018	0,018	0,018	0,020
8,3	0,017	0,016	0,016	0,017	0,016	0,018	0,017	0,017	0,017	0,017	0,019
8,5	0,017	0,017	0,015	0,017	0,015	0,017	0,018	0,018	0,018	0,018	0,019
8,7	0,018	0,018	0,015	0,017	0,015	0,017	0,017	0,018	0,018	0,018	0,020
8,9	0,020	0,018	0,016	0,018	0,016	0,017	0,017	0,021	0,022	0,020	0,021
<b>Note:</b> The normalization current is 43,478A.											

<b>4.8</b>	<b>EMC and power quality Harmonic current emission (EN 61000-4-7)</b>	<b>P</b>
------------	---	----------

The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A, The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.

**Test result: ASW50K-LT-G2**

**Harmonics**

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
1	2,418	10,495	20,717	30,581	40,853	50,826	60,867	70,702	80,676	90,547	98,216
2	0,110	0,106	0,110	0,128	0,109	0,111	0,106	0,108	0,117	0,126	0,140
3	0,173	0,328	0,413	0,341	0,281	0,252	0,342	0,243	0,251	0,265	0,268
4	0,158	0,028	0,069	0,091	0,091	0,123	0,103	0,123	0,144	0,161	0,180
5	0,227	0,267	0,245	0,306	0,300	0,320	0,325	0,330	0,341	0,339	0,343
6	0,027	0,032	0,039	0,058	0,019	0,016	0,021	0,021	0,025	0,037	0,039
7	0,073	0,045	0,074	0,094	0,118	0,122	0,121	0,125	0,120	0,135	0,140
8	0,197	0,022	0,028	0,052	0,021	0,026	0,032	0,038	0,045	0,056	0,064
9	0,039	0,110	0,032	0,105	0,060	0,058	0,065	0,076	0,067	0,072	0,071
10	0,163	0,018	0,018	0,030	0,019	0,021	0,028	0,031	0,036	0,046	0,051
11	0,143	0,063	0,059	0,044	0,043	0,047	0,101	0,117	0,110	0,099	0,094
12	0,025	0,018	0,030	0,027	0,015	0,012	0,020	0,020	0,027	0,030	0,027
13	0,100	0,097	0,063	0,074	0,049	0,058	0,099	0,114	0,115	0,107	0,105
14	0,092	0,018	0,029	0,025	0,017	0,020	0,027	0,030	0,040	0,066	0,100
15	0,050	0,088	0,047	0,121	0,054	0,050	0,068	0,072	0,074	0,080	0,074
16	0,162	0,013	0,017	0,019	0,017	0,024	0,029	0,031	0,041	0,066	0,100
17	0,644	0,221	0,162	0,173	0,116	0,115	0,167	0,201	0,207	0,247	0,266
18	0,018	0,014	0,022	0,015	0,013	0,012	0,015	0,016	0,019	0,023	0,023
19	0,124	0,304	0,195	0,157	0,095	0,114	0,163	0,197	0,226	0,244	0,281
20	0,088	0,018	0,019	0,015	0,015	0,018	0,023	0,028	0,034	0,039	0,043
21	0,066	0,065	0,044	0,033	0,041	0,046	0,048	0,058	0,060	0,063	0,060
22	0,040	0,015	0,016	0,015	0,018	0,023	0,029	0,035	0,041	0,049	0,053
23	0,116	0,153	0,157	0,098	0,086	0,106	0,125	0,151	0,176	0,193	0,204
24	0,016	0,011	0,013	0,011	0,012	0,012	0,012	0,015	0,019	0,023	0,022
25	0,222	0,166	0,154	0,092	0,077	0,096	0,123	0,159	0,188	0,213	0,228
26	0,138	0,018	0,012	0,013	0,016	0,021	0,023	0,029	0,035	0,040	0,043
27	0,054	0,055	0,025	0,011	0,028	0,039	0,042	0,044	0,051	0,051	0,053
28	0,117	0,018	0,013	0,014	0,019	0,025	0,030	0,034	0,042	0,049	0,053
29	0,190	0,164	0,096	0,053	0,068	0,082	0,101	0,116	0,139	0,155	0,166
30	0,023	0,012	0,015	0,012	0,012	0,011	0,012	0,014	0,017	0,021	0,021
31	0,282	0,139	0,092	0,052	0,061	0,085	0,105	0,128	0,153	0,174	0,188
32	0,105	0,018	0,016	0,013	0,016	0,021	0,024	0,028	0,033	0,038	0,042
33	0,054	0,052	0,028	0,019	0,027	0,038	0,038	0,041	0,042	0,045	0,045
34	0,134	0,017	0,018	0,017	0,021	0,026	0,028	0,032	0,039	0,045	0,050
35	0,168	0,143	0,081	0,068	0,075	0,090	0,095	0,107	0,122	0,140	0,148
36	0,027	0,013	0,020	0,014	0,015	0,012	0,013	0,014	0,018	0,020	0,020
37	0,175	0,128	0,084	0,038	0,047	0,068	0,084	0,100	0,119	0,137	0,148
38	0,048	0,019	0,026	0,017	0,021	0,024	0,024	0,028	0,034	0,036	0,040
39	0,051	0,086	0,068	0,091	0,092	0,091	0,086	0,087	0,094	0,102	0,098
40	0,073	0,021	0,032	0,020	0,021	0,023	0,029	0,033	0,035	0,043	0,046



4.8 EMC and power quality Harmonic current emission (EN 61000-4-7)											P
The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A, The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.											
<b>Test result: ASW50K-LT-G2</b>											
<b>Interharmonics</b>											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [Hz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
75	0,054	0,077	0,272	0,291	0,272	0,345	0,417	0,478	0,547	0,630	0,696
125	0,056	0,075	0,281	0,318	0,269	0,350	0,411	0,465	0,539	0,613	0,688
175	0,033	0,023	0,072	0,095	0,053	0,058	0,070	0,080	0,091	0,135	0,162
225	0,029	0,021	0,049	0,160	0,036	0,046	0,055	0,061	0,074	0,134	0,158
275	0,031	0,028	0,048	0,046	0,024	0,027	0,028	0,032	0,038	0,089	0,092
325	0,044	0,049	0,074	0,077	0,036	0,034	0,032	0,038	0,045	0,074	0,068
375	0,028	0,031	0,044	0,039	0,022	0,021	0,019	0,024	0,025	0,070	0,053
425	0,040	0,041	0,066	0,049	0,030	0,031	0,026	0,028	0,031	0,042	0,049
475	0,022	0,016	0,029	0,027	0,019	0,018	0,019	0,019	0,020	0,052	0,060
525	0,017	0,016	0,016	0,020	0,013	0,014	0,018	0,018	0,020	0,025	0,032
575	0,024	0,021	0,029	0,082	0,017	0,017	0,022	0,026	0,031	0,040	0,052
625	0,036	0,039	0,055	0,041	0,031	0,027	0,124	0,126	0,169	0,073	0,052
675	0,022	0,023	0,092	0,109	0,018	0,017	0,025	0,030	0,035	0,033	0,039
725	0,041	0,048	0,052	0,045	0,031	0,028	0,118	0,119	0,168	0,075	0,061
775	0,021	0,019	0,132	0,115	0,019	0,017	0,016	0,020	0,022	0,209	0,198
825	0,018	0,013	0,020	0,025	0,013	0,013	0,016	0,016	0,017	0,038	0,038
875	0,031	0,035	0,032	0,037	0,023	0,023	0,026	0,028	0,029	0,216	0,205
925	0,030	0,038	0,032	0,028	0,021	0,019	0,025	0,031	0,031	0,041	0,039
975	0,026	0,037	0,039	0,035	0,027	0,026	0,028	0,031	0,035	0,041	0,042
1025	0,032	0,042	0,037	0,028	0,022	0,024	0,027	0,035	0,037	0,040	0,043
1075	0,027	0,027	0,018	0,020	0,019	0,015	0,017	0,018	0,019	0,019	0,020
1125	0,017	0,012	0,017	0,013	0,014	0,013	0,013	0,016	0,015	0,017	0,019
1175	0,032	0,035	0,029	0,035	0,025	0,025	0,026	0,032	0,032	0,035	0,041
1225	0,034	0,037	0,030	0,025	0,022	0,022	0,026	0,030	0,035	0,038	0,038
1275	0,024	0,030	0,035	0,034	0,030	0,028	0,030	0,033	0,039	0,042	0,045
1325	0,031	0,041	0,034	0,027	0,024	0,026	0,028	0,035	0,040	0,046	0,046
1375	0,036	0,024	0,019	0,022	0,017	0,016	0,018	0,017	0,020	0,019	0,020
1425	0,016	0,012	0,016	0,011	0,013	0,013	0,013	0,014	0,015	0,020	0,018
1475	0,034	0,036	0,034	0,035	0,026	0,026	0,030	0,031	0,036	0,036	0,042
1525	0,031	0,032	0,026	0,023	0,024	0,023	0,027	0,028	0,035	0,038	0,038
1575	0,022	0,029	0,042	0,033	0,031	0,028	0,034	0,033	0,040	0,041	0,044
1625	0,026	0,035	0,030	0,023	0,024	0,027	0,028	0,033	0,038	0,044	0,046
1675	0,200	0,107	0,044	0,084	0,085	0,082	0,063	0,068	0,070	0,067	0,060
1725	0,018	0,015	0,021	0,018	0,021	0,023	0,016	0,019	0,019	0,021	0,023
1775	0,249	0,293	0,178	0,296	0,306	0,317	0,259	0,269	0,274	0,275	0,279
1825	0,033	0,032	0,033	0,028	0,032	0,029	0,032	0,033	0,036	0,041	0,039
1875	0,025	0,036	0,091	0,030	0,028	0,029	0,033	0,033	0,040	0,041	0,043
1925	0,027	0,024	0,034	0,024	0,027	0,028	0,029	0,033	0,039	0,042	0,045
1975	0,183	0,373	0,338	0,413	0,423	0,431	0,370	0,390	0,401	0,423	0,451

<b>4.8</b>	<b>EMC and power quality Harmonic current emission (EN 61000-4-7)</b>	<b>P</b>
------------	---	----------

The currents of the interharmonics to 2 kHz must be measured in accordance with DIN EN 61000-4-7 (VDE 0817-4-7), Annex A, The measurements of higher-frequency harmonic currents between 2 kHz and 9 kHz must be conducted in line with DIN EN 61000-4-7 (VDE 0847-4-7), Annex B.

**Test result: ASW50K-LT-G2**

**Higher Frequencies**

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2,1	0,273	0,358	0,332	0,376	0,388	0,399	0,351	0,359	0,377	0,403	0,423
2,3	0,354	0,354	0,232	0,358	0,365	0,376	0,300	0,312	0,325	0,327	0,331
2,5	0,163	0,078	0,069	0,045	0,051	0,062	0,074	0,083	0,094	0,109	0,117
2,7	0,124	0,082	0,063	0,047	0,054	0,064	0,072	0,083	0,094	0,107	0,116
2,9	0,121	0,074	0,048	0,035	0,042	0,045	0,054	0,061	0,066	0,074	0,082
3,1	0,087	0,065	0,050	0,031	0,044	0,050	0,051	0,064	0,070	0,078	0,087
3,3	0,109	0,057	0,044	0,032	0,047	0,056	0,057	0,066	0,076	0,083	0,089
3,5	0,081	0,037	0,043	0,042	0,051	0,054	0,055	0,063	0,072	0,078	0,084
3,7	0,065	0,035	0,030	0,024	0,031	0,032	0,031	0,035	0,041	0,047	0,054
3,9	0,057	0,031	0,031	0,023	0,028	0,029	0,026	0,028	0,029	0,033	0,033
4,1	0,037	0,024	0,026	0,019	0,027	0,029	0,022	0,030	0,032	0,038	0,041
4,3	0,037	0,023	0,022	0,019	0,028	0,031	0,022	0,029	0,031	0,037	0,039
4,5	0,033	0,021	0,019	0,017	0,021	0,020	0,020	0,024	0,025	0,026	0,025
4,7	0,025	0,019	0,019	0,018	0,021	0,020	0,019	0,023	0,025	0,025	0,025
4,9	0,021	0,017	0,018	0,017	0,017	0,015	0,016	0,020	0,022	0,022	0,021
5,1	0,021	0,017	0,017	0,017	0,017	0,014	0,015	0,019	0,021	0,022	0,021
5,3	0,017	0,017	0,017	0,017	0,017	0,015	0,014	0,018	0,019	0,022	0,020
5,5	0,014	0,017	0,018	0,017	0,017	0,014	0,013	0,017	0,018	0,021	0,019
5,7	0,014	0,018	0,018	0,018	0,016	0,014	0,013	0,017	0,018	0,020	0,019
5,9	0,013	0,019	0,019	0,019	0,017	0,016	0,013	0,017	0,018	0,019	0,018
6,1	0,013	0,019	0,019	0,019	0,018	0,015	0,012	0,018	0,019	0,020	0,019
6,3	0,013	0,019	0,019	0,019	0,016	0,015	0,012	0,017	0,018	0,020	0,019
6,5	0,014	0,020	0,020	0,019	0,017	0,015	0,012	0,017	0,018	0,019	0,018
6,7	0,014	0,019	0,018	0,019	0,017	0,014	0,013	0,018	0,019	0,018	0,018
6,9	0,015	0,019	0,018	0,018	0,017	0,014	0,014	0,018	0,018	0,018	0,018
7,1	0,018	0,021	0,020	0,022	0,023	0,022	0,018	0,024	0,024	0,024	0,025
7,3	0,021	0,019	0,017	0,017	0,018	0,015	0,012	0,020	0,018	0,018	0,019
7,5	0,020	0,021	0,018	0,021	0,023	0,022	0,018	0,023	0,024	0,024	0,024
7,7	0,013	0,017	0,016	0,016	0,019	0,015	0,011	0,018	0,019	0,018	0,019
7,9	0,013	0,016	0,016	0,016	0,018	0,015	0,011	0,018	0,019	0,018	0,019
8,1	0,012	0,016	0,016	0,017	0,019	0,015	0,011	0,018	0,019	0,018	0,020
8,3	0,012	0,016	0,017	0,017	0,019	0,017	0,011	0,018	0,019	0,018	0,019
8,5	0,012	0,016	0,017	0,017	0,018	0,016	0,011	0,018	0,019	0,018	0,019
8,7	0,012	0,016	0,017	0,017	0,019	0,016	0,011	0,019	0,019	0,020	0,019
8,9	0,013	0,017	0,018	0,017	0,018	0,016	0,012	0,019	0,019	0,021	0,020

**Note:** The normalization current is 72,464 A.

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

4.8 EMC and power quality Switching operation (Refer IEC 61400-21)		P			
<b>Test result:</b>					
Max. number of switching operations, $N_{10}$	10				
Max. number of switching operations, $N_{120}$	120				
Case of switching operation	Cut-in at 10% $P_{E_{max}}$				
Grid impedance angle, $\psi_k$	30°	50°	70°	85°	
Flicker step factor, $k_f(\psi_k)$	0,018	0,012	0,010	0,009	
Voltage change factor, $k_u(\psi_k)$	0,207	0,218	0,214	0,215	
Maximum inrush current factor $k_{imax}$	0,14				
Case of switching operation	Cut-in at 100% $P_{E_{max}}$				
Grid impedance angle, $\psi_k$	30°	50°	70°	85°	
Flicker step factor, $k_f(\psi_k)$	0,032	0,021	0,017	0,016	
Voltage change factor, $k_u(\psi_k)$	0,207	0,209	0,208	0,202	
Maximum inrush current factor $k_{imax}$	0,38				
Case of switching operation	Service disconnection at rated power				
Grid impedance angle, $\psi_k$	30°	50°	70°	85°	
Flicker step factor, $k_f(\psi_k)$	0,010	0,008	0,006	0,005	
Voltage change factor, $k_u(\psi_k)$	0,213	0,241	0,230	0,219	
Maximum inrush current factor $k_{imax}$	0,70				
Worst case over all switching operations, $k_{imax}$	0,70				
<b>Note:</b>					
<p><math>S_{k, fic}/S_n</math> in the fictitious grid was set to:20.</p> <p>The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.</p>					

<b>4.8</b>	<b>Voltage fluctuation and flicker</b>	<b>P</b>
------------	--	----------

**Test result:**

**Test conditions:**

Maximum permissible voltage fluctuation (expressed as a percentage of nominal voltage at 100 % power) and flicker as per EN 61000-3-3 and/or EN 61000-3-11.

**Test:ASW50K-LT-G2**

Value	$P_{st}$	$P_{lt}$ 2 hours	$d(t)_{500ms}$	$d_c$	$d_{max}$
<b>Limit</b>	1,0	0,65	3,3%	3,3%	4%
<b>Test value</b>	See below				

**Inverter >16A**

**L1 phase**

	$d_c$ [%]	$d_{max}$ [%]	$d(t)$ [ms]	$P_{st}$	$P_{lt}$
<b>Limit</b>	3.30	4.00	500 3.30(%)	1.00	0.65 N: 12
<b>No. 1</b>	0.11 Pass	0.22 Pass	0 Pass	0.15 Pass	
<b>2</b>	0.11 Pass	0.20 Pass	0 Pass	0.15 Pass	
<b>3</b>	0.11 Pass	0.21 Pass	0 Pass	0.15 Pass	
<b>4</b>	0.10 Pass	0.25 Pass	0 Pass	0.15 Pass	
<b>5</b>	0.11 Pass	0.19 Pass	0 Pass	0.15 Pass	
<b>6</b>	0.11 Pass	0.20 Pass	0 Pass	0.15 Pass	
<b>7</b>	0.11 Pass	0.21 Pass	0 Pass	0.15 Pass	
<b>8</b>	0.11 Pass	0.21 Pass	0 Pass	0.15 Pass	
<b>9</b>	0.12 Pass	0.20 Pass	0 Pass	0.15 Pass	
<b>10</b>	0.11 Pass	0.20 Pass	0 Pass	0.15 Pass	
<b>11</b>	0.10 Pass	0.20 Pass	0 Pass	0.15 Pass	
<b>12</b>	0.11 Pass	0.20 Pass	0 Pass	0.15 Pass	
<b>Result</b>	Pass	Pass	Pass	Pass	0.15 Pass

**L2 phase**

	$d_c$ [%]	$d_{max}$ [%]	$d(t)$ [ms]	$P_{st}$	$P_{lt}$
<b>Limit</b>	3.30	4.00	500 3.30(%)	1.00	0.65 N: 12
<b>No. 1</b>	0.11 Pass	0.77 Pass	0 Pass	0.17 Pass	
<b>2</b>	0.11 Pass	0.77 Pass	0 Pass	0.18 Pass	
<b>3</b>	0.11 Pass	0.81 Pass	0 Pass	0.17 Pass	
<b>4</b>	0.10 Pass	0.83 Pass	0 Pass	0.18 Pass	
<b>5</b>	0.11 Pass	0.83 Pass	0 Pass	0.18 Pass	
<b>6</b>	0.11 Pass	0.87 Pass	0 Pass	0.18 Pass	
<b>7</b>	0.11 Pass	0.87 Pass	0 Pass	0.17 Pass	
<b>8</b>	0.11 Pass	0.87 Pass	0 Pass	0.18 Pass	
<b>9</b>	0.12 Pass	0.87 Pass	0 Pass	0.18 Pass	
<b>10</b>	0.11 Pass	0.87 Pass	0 Pass	0.18 Pass	
<b>11</b>	0.10 Pass	0.87 Pass	0 Pass	0.18 Pass	
<b>12</b>	0.11 Pass	0.87 Pass	0 Pass	0.18 Pass	
<b>Result</b>	Pass	Pass	Pass	Pass	0.18 Pass

L3 phase

	dc[%]	dmax[%]	d(t)[ms]	Pst	P1t
<b>Limit</b>	<b>3.30</b>	<b>4.00</b>	<b>500</b> <b>3.30(%)</b>	<b>1.00</b>	<b>0.65</b> <b>N:12</b>
<b>No. 1</b>	<b>0.08 Pass</b>	<b>0.30 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>2</b>	<b>0.08 Pass</b>	<b>0.26 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>3</b>	<b>0.07 Pass</b>	<b>0.25 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>4</b>	<b>0.08 Pass</b>	<b>0.25 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>5</b>	<b>0.08 Pass</b>	<b>0.28 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>6</b>	<b>0.08 Pass</b>	<b>0.25 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>7</b>	<b>0.07 Pass</b>	<b>0.31 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>8</b>	<b>0.06 Pass</b>	<b>0.25 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>9</b>	<b>0.06 Pass</b>	<b>0.26 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>10</b>	<b>0.05 Pass</b>	<b>0.25 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>11</b>	<b>0.08 Pass</b>	<b>0.24 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>12</b>	<b>0.07 Pass</b>	<b>0.31 Pass</b>	<b>0 Pass</b>	<b>0.20 Pass</b>	
<b>Result</b>	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>	<b>0.20 Pass</b>

Note:

\*The stationary deviance of dc% is more relevant than the dynamic deviance of dmax at starting and stopping, Mains Impedance according EN61000-3-11:

**$R_{max} = 0,24\Omega$ ;  $jX_{max} = 0,15\Omega$  @50Hz ( $|Z_{max}| = 0,283/0,4717\Omega$ ) for single phase inverter use also  $R_n = 0,16\Omega$ ;  $jX_n = 0,1\Omega$ .**

Calculation of the maximum permissible grid impedance at the point of common coupling based on dc:


**$Z_{max} = Z_{ref} * 3,3\% / d_c(P_n)$ .**

The tests should be based on the limits of the EN 61000-3-11 for more than 16A.

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

4.8 EMC and power quality Flicker and voltage fluctuations											P
Method: Measurement and evaluation was carried out according to the procedure in IEC 61400-21.											
<b>Test result:</b>											
Grid impedance angle, $\psi_k$	30°		50°		70°		85°				
Operating point, $P_a/P_{E_{max}}$ [%]	Flicker coefficient, $c(\psi_k)$										
3	0,170		0,170		0,155		0,155				
10	0,180		0,180		0,164		0,164				
20	0,170		0,170		0,155		0,155				
30	0,180		0,180		0,164		0,164				
40	0,180		0,180		0,164		0,164				
50	0,180		0,180		0,164		0,164				
60	0,170		0,170		0,155		0,155				
70	0,180		0,180		0,164		0,164				
80	0,180		0,180		0,164		0,164				
90	0,180		0,180		0,164		0,164				
100	0,180		0,180		0,164		0,164				
Max. Flicker coefficient, $c(\psi_k)$	1,14		0,75		0,61		0,57				
Max. Short-term flicker, Pst	0,180		0,180		0,164		0,164				
Reactive power setpoint during testing [kVar]											0
P [% $P_{E_{max}}$ ]	3	10	20	30	40	50	60	70	80	90	100
Number of data sets	1	1	1	1	1	1	1	1	1	1	1
<b>Note:</b> The table entries are worst case values. $S_{k, fic}/S_n$ in the fictitious grid was set to:20. The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.											

Maximum Flicker coefficients  $c(\psi_k)$  vs. power bins




4.8 EMC and power quality DC-Injection		P			
<b>Test result: ASW30K-LT-G2</b>					
Protection limit	Tested at four power levels limit 0,5% of $I_{AC,nom}$ (217mA)				
Output power	~25%	~50%	~70%	~100%	
Abs. Max. Test Value:L1 [A]	0,120	0,093	0,097	0,121	
Abs. Ave. Test Value:L1 [A]	0,036	0,032	0,034	0,045	
Abs. Max. Test Value:L2 [A]	0,082	0,086	0,128	0,136	
Abs. Ave. Test Value:L2 [A]	0,022	0,043	0,062	0,068	
Abs. Max. Test Value:L3 [A]	0,097	0,065	0,09	0,125	
Abs. Ave. Test Value:L3 [A]	0,023	0,023	0,030	0,047	
<b>Test result: ASW50K-LT-G2</b>					
Protection limit	Tested at four power levels limit 0,5% of $I_{AC,nom}$ (362mA)				
Output power	~25%	~50%	~70%	~100%	
Abs. Max. Test Value:L1 [A]	0,102	0,115	0,135	0,333	
Abs. Ave. Test Value:L1 [A]	0,064	0,045	0,059	0,236	
Abs. Max. Test Value:L2 [A]	0,081	0,122	0,172	0,137	
Abs. Ave. Test Value:L2 [A]	0,044	0,061	0,091	0,049	
Abs. Max. Test Value:L3 [A]	0,050	0,072	0,098	0,126	
Abs. Ave. Test Value:L3 [A]	0,018	0,026	0,039	0,036	
<b>Note:</b>					
Test method and setting value refer Annex D.3.10 of EN 50438:2013.					
Testing must be performed according to WI 10.4.-03.doc rev D. The internal temperature of the EUT must be stabilized, No temperature drift of more than 2K within 1 hour is allowed.					
The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.					




**Diagram of permanent dc-injection**

**ASW30K-LT-G2**




**ASW50K-LT-G2**




4.8 Immunity to voltage dips and short interruptions					P
For a directly coupled SSEG			For a Inverter SSEG		
L1					
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	$I_p$	N/A	20ms	24,65Vac	11,99A
Initial Value of aperiodic current	A	N/A	100ms	14,19Vac	7,99A
Initial symmetrical short-circuit current*	$I_k$	N/A	250ms	N/A	N/A
Decaying (aperiodic) component of short circuit current*	$i_{DC}$	N/A	500ms	N/A	N/A
L2					
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	$I_p$	N/A	20ms	55,88Vac	26,91A
Initial Value of aperiodic current	A	N/A	100ms	26,65Vac	13,64A
Initial symmetrical short-circuit current*	$I_k$	N/A	250ms	N/A	N/A
Decaying (aperiodic) component of short circuit current*	$i_{DC}$	N/A	500ms	N/A	N/A
L3					
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	$I_p$	N/A	20ms	34,79Vac	25,55A
Initial Value of aperiodic current	A	N/A	100ms	17,99Vac	11,81A
Initial symmetrical short-circuit current*	$I_k$	N/A	250ms	N/A	N/A
Decaying (aperiodic) component of short circuit current*	$i_{DC}$	N/A	500ms	N/A	N/A
Reactance/Resistance Ratio of source*	X/R	N/A	Time to trip	0,033s	In seconds
<p><b>Note:</b></p> <p>For rotating machines and linear piston machines the test should produce a 0s – 2s plot of the short circuit current as seen at the Generating Unit terminals.</p> <p>* Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot.</p> <p>The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.</p>					

Graphs:



4.8 Unbalance								P
Test: cos φ = 1								
P [%P <sub>max</sub> ]	P* [kW]	U <sub>1+*</sub> [V]	U <sub>1-*</sub> [V]	I <sub>1+*</sub> [A]	I <sub>1-*</sub> [A]	U <sub>i*</sub> [% I <sub>1+</sub> ]	U <sub>i abs*</sub> [% I <sub>n</sub> ]	Number of data sets
0 - 5	0,194	230,03	0,087	0,280	0,089	31,79	0,123	3
10	5,376	229,32	0,087	7,815	0,066	0,84	0,091	3
20	10,592	229,53	0,464	15,381	0,186	1,21	0,257	3
30	15,806	228,95	0,102	23,012	0,176	0,76	0,243	3
40	20,959	229,28	0,109	30,471	0,199	0,65	0,275	3
50	26,045	229,60	0,12	38,813	0,197	0,51	0,272	3
60	31,05	229,93	0,117	45,014	0,223	0,50	0,308	3
70	35,957	230,25	0,120	52,054	0,227	0,44	0,313	3
80	40,754	230,58	0,124	58,916	0,216	0,37	0,298	3
90	45,371	230,89	0,137	65,502	0,240	0,37	0,331	3
100	49,342	231,12	0,126	71,162	0,187	0,26	0,258	3
Maximum unsymmetry U <sub>imax</sub> (≥10%P <sub>n</sub> )					0,002			
<p>Note:</p> <p>*1 min-average values of positive and negative sequence data.</p> <p>The unsymmetry is calculated according to following equation:</p> $u_i = \frac{I_{1-}}{I_{1+}} \cdot 100\%$ <p>Additionally the unsymmetry is calculated relative to nominal current according to following equation:</p> $u_{\text{abs}} = \frac{I_{1-}}{I_n} \cdot 100\%$ <p>The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.</p>								

Diagram



### EN 50549-1:2019: Interface protection

Clause	Test requirement	Test procedure according standard	Result
4.9.3	Requirements on voltage and frequency protection	CEI 0-21:2019-04, Annex A.3.1 to A.3.4	P
4.9.3.1	Undervoltage protection	EN 50438, Annex D.2.3	P
	Overvoltage protection	EN 50438, Annex D.2.3	P
	Overvoltage 10 min mean protection	EN 50160	P
	Underfrequency protection	EN 50438, Annex D.2.4	P
	Overfrequency protection	EN 50438, Annex D.2.4	P
4.9.4.2	Loss of Mains (LoM) detection	IEC 62116:2014	P

<b>4.9.3 Requirements on voltage and frequency protection Checklist</b>						<b>P</b>
<b>Several points to check</b>						
Clause 4.9.3.1 to 4.9.3.6	All thresholds must be adjustable					<b>P</b>
<b>Voltage values</b>						
Threshold	Stage 1 [27 <]			Stage 2 [27 <<]		
	Operate voltage		Operate time	Operate voltage		Operate time
Range	0,2-1,0 U <sub>n</sub>		0,1-100s	0,2-1,0 U <sub>n</sub>		0,1-5s
Steps	0,01 U <sub>n</sub>		0,1 s	0,01 U <sub>n</sub>		0,05s
Threshold	Stage 1 [59 >]		Stage 2 [59 >>]		Overvoltage 10 min mean protection	
	Operate voltage	Operate time	Operate voltage	Operate time	Operate voltage	Operate time
Range	1,0-1,2 U <sub>n</sub>	0,1-100s	1,0-1,3 U <sub>n</sub>	0,1-5s	1,0-1,15 U <sub>n</sub>	3s not adjustable
Steps	0,01 U <sub>n</sub>	0,1s	0,01 U <sub>n</sub>	0,05s	0,01 U <sub>n</sub>	--
<b>Frequency values</b>						
Threshold	Stage 1 [81 <]			Stage 2 [81 <<]		
	Operate frequency		Operate time	Operate frequency		Operate time
Range	47,0-50,0Hz		0,1-100s	47,0-50,0Hz		0,1-5s
Steps	0,1 Hz		0,1 s	0,1 Hz		0,05s
Threshold	Stage 1 [81 >]			Stage 2 [81 >>]		
	Operate frequency		Operate time	Operate frequency		Operate time
Range	50,0-52,0Hz		0,1-100s	50,0-52,0Hz		0,1-5s
Steps	0,1 Hz		0,1 s	0,1 Hz		0,05s
4.9.2.6	Insensitive against 40ms frequency transients, so that the unit will not trip					<b>P</b>
<b>Note:</b>						

4.9.3 Requirements on voltage and frequency protection					P
4.9.3.1 General (Interface protection: Over/under voltage) (Setting value refer EN 50549-1 for default settings)					
Test conditions			Output power: 20,0kW Frequency: 50+/-0,2Hz		
Phase	Limit [V]	Trip value [V]	Voltage step [V]	Disconnection time [s]	Limit [s]
L1	Stage 1 115% of $U_n$ = 264,5	264,0	230 to 269	0,135	$\leq 3,0s$
		263,9	230 to 269	0,130	
		263,9	230 to 269	0,133	
		264,1	230 to 269	0,153	
		263,9	230 to 269	0,138	
	Stage 2 125% of $U_n$ = 287,5	287,8	230 to 292	0,128	$0,1s \leq t \leq 0,2s$
		287,6	230 to 292	0,124	
		287,5	230 to 292	0,129	
		287,7	230 to 292	0,129	
		287,8	230 to 292	0,129	
	Stage 80% of $U_n$ = 184	184,4	230 to 189	2,547	$2,0s \leq t \leq 5,0s$
		184,4	230 to 189	2,512	
		184,3	230 to 189	2,542	
		184,2	230 to 189	2,547	
		184,4	230 to 189	2,522	
	Stage 2 50% of $U_n$ = 115	115,9	230 to 120	0,135	$0,1s \leq t \leq 2,0s$
		115,7	230 to 120	0,140	
		115,9	230 to 120	0,135	
		115,8	230 to 120	0,125	
		115,8	230 to 120	0,115	
L2	Stage 1 115% of $U_n$ = 264,5	263,9	230 to 269	0,153	$\leq 3,0s$
		263,8	230 to 269	0,143	
		263,9	230 to 269	0,148	
		263,8	230 to 269	0,138	
		263,8	230 to 269	0,163	
	Stage 2 125% of $U_n$ = 287,5	287,3	230 to 292	0,134	$0,1s \leq t \leq 0,2s$
		287,5	230 to 292	0,124	
		287,2	230 to 292	0,132	
		287,3	230 to 292	0,143	
		287,4	230 to 292	0,128	
	Stage 80% of $U_n$ = 184	184,1	230 to 189	2,522	$2,0s \leq t \leq 5,0s$
		184,3	230 to 189	2,522	
		184,2	230 to 189	2,522	
		184,2	230 to 189	2,542	
		184,1	230 to 189	2,532	
	Stage 2 50% of $U_n$ = 115	115,7	230 to 120	0,125	$0,1s \leq t \leq 2,0s$
		115,5	230 to 120	0,125	
		115,8	230 to 120	0,135	
		115,6	230 to 120	0,135	
		115,7	230 to 120	0,125	



4.9.3 Requirements on voltage and frequency protection				P	
4.9.3.1 General (Interface protection: Over/under voltage) (Setting value refer EN 50549-1 for default settings)					
Test conditions			Output power: 20,0kW Frequency: 50+/-0,2Hz		
Phase	Limit [V]	Trip value [V]	Voltage step [V]	Disconnection time [s]	Limit [s]
L3	Stage 1 115% of $U_n$ = 264,5	263,4	230 to 269	0,133	≤3,0s
		263,5	230 to 269	0,133	
		263,5	230 to 269	0,148	
		263,8	230 to 269	0,143	
		263,8	230 to 269	0,138	
	Stage 2 125% of $U_n$ = 287,5	287,7	230 to 292	0,138	0,1s ≤ t ≤ 0,2s
		287,9	230 to 292	0,133	
		287,6	230 to 292	0,138	
		287,7	230 to 292	0,138	
		287,8	230 to 292	0,138	
	Stage 80% of $U_n$ = 184	184,4	230 to 189	2,532	2,0s ≤ t ≤ 5,0s
		184,5	230 to 189	2,557	
		184,3	230 to 189	2,537	
		184,6	230 to 189	2,537	
		184,5	230 to 189	2,537	
	Stage 2 50% of $U_n$ = 115	115,2	230 to 120	0,130	0,1s ≤ t ≤ 2,0s
		115,5	230 to 120	0,130	
		115,4	230 to 120	0,135	
		115,6	230 to 120	0,135	
		115,5	230 to 120	0,140	

**Note:**  
The trip values were evaluated by varying the applied voltage from  $U_n$  down to  $U_{th-low} - 2\%$  of  $U_n$  in steps of 0,5% of  $U_n$  for under-voltage testing as well as from  $U_n$  up to  $U_{th-high} + 2\%$  of  $U_n$  in steps of 0,5% of  $U_n$  for over-voltage testing, Lower and upper threshold voltage shall not fall or rise below or above 2,3V of the trip value itself, The disconnection time was measured by application of a negative voltage step from  $U_n$  to the operate value -5% of  $U_n$  as well as positive voltage step from  $U_n$  to the operate value +5% of  $U_n$ .


The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

### Scope pictures of the disconnection time

#### Over-voltage - Stage 1 (L1 phase)



#### Over-voltage - Stage 2 (L1 phase)




### Scope pictures of the disconnection time

#### Under-voltage - Stage 1 (L1 phase)



#### Under-voltage - Stage 2 (L1 phase)




### Scope pictures of the disconnection time

#### Over-voltage - Stage 1 (L2 phase)



#### Over-voltage - Stage 2 (L2 phase)



### Scope pictures of the disconnection time

#### Under-voltage - Stage 1 (L2 phase)




#### Under-voltage - Stage 2 (L2 phase)



Scope pictures of the disconnection time

Over-voltage - Stage 1 (L3 phase)



Over-voltage - Stage 2 (L3 phase)



### Scope pictures of the disconnection time

#### Under-voltage - Stage 1 (L3 phase)




#### Under-voltage - Stage 2 (L3 phase)




4.9.3 Requirements on voltage and frequency protection		P
4.9.3.1 General (Maximum voltage 10 min mean protection according to EN 50160) (Setting value refer EN 50438 for default settings)		
Setting values of the protection:	Trip value Setting [V]	253
	Setting $T_{\text{disconnection trip value}}$ [s]	600
	Setting $T_{\text{disconnection}}$ [ms]	200
<b>Test:</b>		
	Disconnection time [s]	Limit [s]
a)	The voltage is set to 100% $U_n$ and held for 600 s, Thereafter the voltage is set to 112% $U_n$ , Disconnection must take place within 600 s,	
	Phase 1:	470 s
	Phase 2:	461 s
	Phase 3:	461 s
		≤ 600 s
b)	The voltage is set to $U_n$ for 600 s and then to 108% $U_n$ for 600 s, No disconnection should take place,	
	Phase 1:	No Disconnection
	Phase 2:	No Disconnection
	Phase 3:	No Disconnection
		Disconnection should not take place,
c)	The voltage is set to 106 % $U_n$ and held for 600 s, Thereafter the voltage is set to 114 % $U_n$ , The disconnection should last for half the period as in Point a)*	
	Phase 1:	286 s
	Phase 2:	253 s
	Phase 3:	252 s
		The disconnection time should be about 50 % of the value measured in a), *
<b>Test:</b>		
a) This test serves as proof of the measurement accuracy and the maximum set time.		
b) This test serves as proof of the measurement accuracy.		
c) This test serves as proof of the correct formation of the 1 minute running mean value.		
<b>Assessment criterion:</b>		
The permitted tolerance between setting value and trip value of the voltage may not exceed $\pm 1 \%$ of $U_N$ .		
<u>Limit values:</u>		
Rise-in voltage protection 1,1 $U_N$ after a max. 600 s, the switch off after 200 ms.		
<b>Note:</b>		
If only one integrated protection is used for the power generation systems, the value of the rise-in voltage protection of 1,1 $U_N$ may not be changed.		
*If the setting value is set to 600 s, then the disconnection time can be in the range between 225 s and 375 s.		
The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.		




a) Voltage set to 112 %  $U_n$ :



b) Voltage set to 108%  $U_n$ :



c) Voltage set to 106 %  $U_n$ , thereafter 114%  $U_n$ :



4.9.3 Requirements on voltage and frequency protection				P
4.9.3.1 General (Interface protection: Over/under frequency)				
Test conditions	Output power: 20,0kW $U_n = 230V_{ac}$			
	Under-frequency		Over-frequency	
Parameter	Stage 1 Under-Frequency	Time	Stage 1 Over-Frequency	Time
Limit	47,50 Hz	$0,3 \leq t \leq 0,5 \text{ s}$	51,50 Hz	$0,3 \leq t \leq 0,5 \text{ s}$
Trip value [Hz]	47,49		51,50	
	47,49		51,50	
	47,49		51,50	
	47,49		51,50	
	47,49		51,50	
Disconnection time [s]	50,00 Hz to 47,40 Hz	0,425	50,00 Hz to 51,60 Hz	0,425
		0,425		0,420
		0,425		0,420
		0,425		0,410
		0,425		0,420
Parameter	Stage 2 Under-Frequency	Time	Stage 2 Over-Frequency	Time
Limit	47,00 Hz	$0,1 \leq t \leq 0,2 \text{ s}$	52,00 Hz	$0,1 \leq t \leq 0,2 \text{ s}$
Trip value [Hz]	47,00		52,01	
	47,00		52,01	
	47,00		52,01	
	47,00		52,01	
	47,00		52,01	
Disconnection time [s]	50,00 Hz to 46,90 Hz	0,135	50,00 Hz to 52,10 Hz	0,140
		0,150		0,140
		0,130		0,145
		0,130		0,135
		0,155		0,145

**Note:**

For under-frequency testing the applied frequency is varied from  $f_n$  down to  $f_{th-low} - 0,1 \text{ Hz}$  in steps of  $0,025 \text{ Hz}$  with a time duration per step exceeding the configured disconnection time, The operate value is the value of the applied frequency at which the protection function trips and shall be within  $f_{th-low} \pm 0,05 \text{ Hz}$ .

For over-frequency testing the applied frequency is varied from  $f_n$  up to  $f_{th-high} + 0,1 \text{ Hz}$  in steps of  $0,025 \text{ Hz}$  with a time duration per step exceeding the configured disconnection time, The operate value is the value of the applied frequency at which the protection function trips and shall be within  $f_{th-high} \pm 0,05 \text{ Hz}$ .


The disconnection time was measured by applying a negative or positive frequency ramp from  $f_n$  to the operate value  $-0,1 \text{ Hz}$  or  $+0,1 \text{ Hz}$ , e.g, from  $50 \text{ Hz}$  to  $47,4 \text{ Hz}$ , The time elapsed between the application of the frequency ramp and the opening of the interface switch was calculated by the measured time minus the  $2500 \text{ ms}$  from  $50,0 \text{ Hz}$  to  $47,5 \text{ Hz}$ .

The oscilloscope pictures below show the measured worst case disconnection times.


The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

### Scope pictures of the disconnection time

#### Under-frequency - Stage 1




#### Over-frequency - Stage 1



### Under-frequency - Stage 2



### Over-frequency - Stage 2



#### 4.9.4.2 Loss of Mains (LoM) detection

Test circuit and parameters

Parameter	Symbol	Units
<b>EUT DC Input</b>		
DC voltage	$V_{DC}$	V
DC Current	$I_{DC}$	A
DC Power	$P_{DC}$	W
<b>EUT AC output</b>		
AC voltage	$V_{EUT}$	V
AC current	$I_{EUT}$	A
Real power	$P_{EUT}$	W
Reactive power	$Q_{EUT}$	VA <sub>r</sub>
<b>Test Load</b>		
Resistive load current	$I_R$	A
Inductive load current	$I_L$	A
Capacitive load current	$I_C$	A
<b>AC (utility) power source</b>		
Utility real power	$P_{AC}$	W
Utility reactive power	$Q_{AC}$	VA <sub>r</sub>
Utility current	$I_{AC}$	A

Block diagram test circuit IEC 62116:2014




Figure 1 – Test circuit for islanding detection function in a power conditioner (inverter)

Load imbalance (real, reactive load) for test condition A (EUT output = 100%)										P
Test :										
Test conditions			Frequency: 50+/-0,1Hz U <sub>N</sub> =230+/-3Vac Distortion factor of chokes < 2% Quality = 1							
Disconnection limit			2s (IEC 62116)							
No	P <sub>EUT</sub> <sup>1)</sup> [% of EUT rating]	Reactive load [% of Q <sub>L</sub> in 6,1,d) <sup>1)</sup>	P <sub>AC</sub> <sup>2)</sup> [% of nominal]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	I <sub>AC</sub> <sup>4)</sup> [A]	P <sub>EUT</sub> [kW per phase]	V <sub>DC</sub> [V]	Q <sub>f</sub>	Run on Time [ms]	Remarks <sup>5)</sup>
1	100	100	0	0	0,225	16,395	740	0,999	582	BL
2	100	100	-10	-10	6,744	16,395	740	1,053	487	IB
3	100	100	-10	-5	7,131	16,395	740	1,082	497	IB
4	100	100	-10	0	7,327	16,395	740	1,110	561	IB
5	100	100	-10	+5	7,331	16,395	740	1,138	521	IB
6	100	100	-10	+10	7,143	16,395	740	1,165	573	IB
7	100	100	-5	-10	3,212	16,395	740	0,998	492	IB
8	100	100	-5	-5	3,578	16,395	740	1,025	580	IB
9	100	100	-5	0	3,764	16,395	740	1,052	519	IB
10	100	100	-5	+5	3,768	16,395	740	1,078	580	IB
11	100	100	-5	+10	3,590	16,395	740	1,103	400	IB
12	100	100	0	-10	0,774	16,395	740	0,948	559	IB
13	100	100	0	-5	0,425	16,395	740	0,974	573	IB
14	100	100	0	+5	0,245	16,395	740	1,024	573	IB
15	100	100	0	+10	0,415	16,395	740	1,048	560	IB
16	100	100	+5	-10	4,312	16,395	740	0,903	492	IB
17	100	100	+5	-5	3,980	16,395	740	0,928	547	IB
18	100	100	+5	0	3,812	16,395	740	0,952	583	IB
19	100	100	+5	+5	3,808	16,395	740	0,975	505	IB
20	100	100	+5	+10	3,970	16,395	740	0,998	525	IB
21	100	100	+10	-10	7,853	16,395	740	0,862	541	IB
22	100	100	+10	-5	7,535	16,395	740	0,885	553	IB
23	100	100	+10	0	7,375	16,395	740	0,908	557	IB
24	100	100	+10	+5	7,371	16,395	740	0,931	549	IB
25	100	100	+10	+10	7,526	16,395	740	0,953	539	IB
Parameter at 0% per phase			L= 10,28mH		R= 3,23Ω			C= 985,53μF		

**Note:**

RLC is adjusted to min. +/-1% of the inverter rated output power

1)  $P_{EUT}$ : EUT output power.

2)  $P_{AC}$ : Real power flow at S1 in Figure 1. Positive means power from EUT to utility, Nominal is the 0 % test condition value.

3)  $Q_{AC}$ : Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility, Nominal is the 0 % test condition value.

4) Fundamental of  $I_{AC}$  when RLC is adjusted.

5) BL: Balance condition, IB: Imbalance condition.

Condition A:

EUT output power  $P_{EUT} = \text{Maximum}$  <sup>6)</sup>

EUT input voltage <sup>6)</sup> = >75% of rated input voltage range


<sup>6)</sup> Maximum EUT output power condition should be achieved using the maximum allowable input power, Actual output power may exceed nominal rated output.

<sup>7)</sup> Based on EUT rated input operating range, For example, If range is between X volts and Y volts, 75 % of range =  $X + 0,75 \times (Y - X)$ , Y shall not exceed  $0,8 \times$  EUT maximum system voltage (i.e., maximum allowable array open circuit voltage), In any case, the EUT should not be operated outside of its allowable input voltage range.

The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

**Scope pictures of the disconnection time**

Disconnection at No. 18






Load imbalance (reactive load) for test condition B (EUT output = 50 % – 66 %)										P
Test :										
Test conditions			Frequency: 50+/-0,1Hz U <sub>N</sub> =230+/-3Vac Distortion factor of chokes < 2% Quality =1							
Disconnection limit			2s (IEC 62116)							
No	P <sub>EUT</sub> <sup>1)</sup> [% of EUT rating]	Reactive load [% of QL in 6,1,d) <sup>1)</sup>	P <sub>AC</sub> <sup>2)</sup> [% of nominal]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	I <sub>AC</sub> <sup>4)</sup> [A]	P <sub>EUT</sub> [kW per phase]	V <sub>DC</sub> [V]	Q <sub>f</sub>	Run on Time [ms]	Remarks <sup>5)</sup>
1	66	66	0	-5	0,295	10,928	500	0,984	495	IB
2	66	66	0	-4	0,272	10,928	500	0,989	515	IB
3	66	66	0	-3	0,255	10,928	500	0,994	524	IB
4	66	66	0	-2	0,243	10,928	500	0,999	536	IB
5	66	66	0	-1	0,235	10,928	500	1,004	569	IB
6	66	66	0	0	0,232	10,928	500	1,009	609	BL
7	66	66	0	+1	0,234	10,928	500	1,014	553	IB
8	66	66	0	+2	0,241	10,928	500	1,019	532	IB
9	66	66	0	+3	0,252	10,928	500	1,024	506	IB
10	66	66	0	+4	0,269	10,928	500	1,029	492	IB
11	66	66	0	+5	0,290	10,928	500	1,034	479	IB
Parameter at 0% per phase			L= 15,27mH		R= 4,84Ω			C= 663,48μF		
<b>Note:</b>										
RLC is adjusted to min. +/-1% of the inverter rated output power										
1) P <sub>EUT</sub> : EUT output power.										
2) P <sub>AC</sub> : Real power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value.										
3) Q <sub>AC</sub> : Reactive power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value.										
4) Fundamental of I <sub>AC</sub> when RLC is adjusted.										
5) BL: Balance condition, IB: Imbalance condition.										
Condition B:										
EUT output power P <sub>EUT</sub> = 50 % – 66 % of maximum										
EUT input voltage <sup>6)</sup> = 50 % of rated input voltage range, ±10 %										
6) Based on EUT rated input operating range, For example, If range is between X volts and Y volts, 50 % of range =X + 0,5 × (Y – X), Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage), In any case, the EUT should not be operated outside of its allowable input voltage range.										
The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.										

Scope pictures of the disconnection time


Disconnection at No, 6



Load imbalance (reactive load) for test condition C (EUT output = 25 % – 33 %)										P
Test :										
Test conditions			Frequency: 50+/-0,1Hz U <sub>N</sub> =230+/-3Vac Distortion factor of chokes < 2% Quality =1							
Disconnection limit			2s (IEC 62116)							
No	P <sub>EUT</sub> <sup>1)</sup> [% of EUT rating]	Reactive load [% of Q <sub>L</sub> in 6,1,d) <sup>1)</sup>	P <sub>AC</sub> <sup>2)</sup> [% of nominal]	Q <sub>AC</sub> <sup>3)</sup> [% of nominal]	I <sub>AC</sub> <sup>4)</sup> [A]	P <sub>EUT</sub> [kW per phase]	V <sub>DC</sub> [V]	Q <sub>f</sub>	Run on Time [ms]	Remarks <sup>5)</sup>
1	33	33	0	-5	0,165	4,980	260	0,979	455	IB
2	33	33	0	-4	0,155	4,980	260	0,984	479	IB
3	33	33	0	-3	0,147	4,980	260	0,989	494	IB
4	33	33	0	-2	0,142	4,980	260	0,994	492	IB
5	33	33	0	-1	0,138	4,980	260	0,999	513	IB
6	33	33	0	0	0,137	4,980	260	1,004	549	BL
7	33	33	0	+1	0,138	4,980	260	1,009	533	IB
8	33	33	0	+2	0,141	4,980	260	1,014	502	IB
9	33	33	0	+3	0,146	4,980	260	1,019	483	IB
10	33	33	0	+4	0,154	4,980	260	1,024	452	IB
11	33	33	0	+5	0,164	4,980	260	1,029	328	IB
Parameter at 0% per phase			L= 33,68mH		R= 10,62Ω			C= 300,86μF		
<b>Note:</b>										
RLC is adjusted to min. +/-1% of the inverter rated output power										
1) P <sub>EUT</sub> : EUT output power.										
2) P <sub>AC</sub> : Real power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value.										
3) Q <sub>AC</sub> : Reactive power flow at S1 in Figure 1, Positive means power from EUT to utility, Nominal is the 0 % test condition value.										
4) Fundamental of I <sub>AC</sub> when RLC is adjusted.										
5) BL: Balance condition, IB: Imbalance condition.										
Condition B:										
EUT output power P <sub>EUT</sub> = 25 % – 33 % <sup>6)</sup> of maximum										
EUT input voltage <sup>7)</sup> = <20 % of rated input voltage range										
6) Or minimum allowable EUT output level if greater than 33 %.										
7) Based on EUT rated input operating range, For example, If range is between X volts and Y volts, 20 % of range = X + 0,2 × (Y – X), Y shall not exceed 0,8 × EUT maximum system voltage (i.e., maximum allowable array open circuit voltage), In any case, the EUT should not be operated outside of its allowable input voltage range.										
The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.										

### Scope pictures of the disconnection time

Disconnection at No, 6




## EN 50549-1:2019: Connection and starting to generate electrical power

Clause	Test requirement	Test procedure according standard	Result
4.10.2	Automatic reconnection after tripping	EN 50438, Annex D.3.6	<b>P</b>
4.10.3	Starting to generate electrical power	EN 50438, Annex D.3.6	<b>P</b>


4.10 Connection and starting to generate electrical power		P
4.10.2 Automatic reconnection after tripping		
4.10.3 Starting to generate electrical power		
Setting value	Min. voltage for connected to grid :	195,5
	Max. voltage for connected to grid :	253,0
	Min. frequency for connected to grid :	49,50
	Max. frequency for connected to grid (Normal operational start-up) :	50,15
	Max. frequency for connected to grid (Automatic reconnection after tripping) :	50,15
	Observation time ( $\geq 60$ s) :	60,00
<b>Test:</b>		
<b>Voltage conditons</b>		
a) Start up for voltage range	<85% $U_n$ for twice of observation time	>110% $U_n$ for twice of observation time
Connection:	No connection	No connection
Limit	No connection allowed	
b) In voltage range at start-up	$\geq 85\% U_n$ within twice setting observation time	$\leq 110\% U_n$ within twice setting observation time
Reconnection time [s]	75,0 s	63,0 s
Limit:	Connected after setting observation time ( $\geq 60$ s)	
Gradient:	The maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: disable, For recorded gradient see diagram below,	
c) In voltage range after voltage failure	$\geq 85\% U_n$ for twice of setting observation time	$\leq 110\% U_n$ for twice of setting observation time
Reconnection time [s]	63,0 s	62,0 s
Limit:	Reconnection after setting observation time ( $\geq 60$ s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: $10\% P_{Emax}/min$ . For non or partly adjustable generators the connection after trip of the interface protection is delayed by a randomised value between 1 min and 10 min. For recorded gradient see diagram below.	
<b>Frequency conditions</b>		
d) Start up for frequency range	<49,50 Hz for twice of setting observation time	>50,15 Hz for twice of setting observation time
Connection:	No connection	No connection
Limit	No connection allowed	

e) In frequency range at start-up	$\geq 49,50$ Hz within twice of setting observation time	$\leq 50,15$ Hz within twice of setting observation time
Reconnection time [s]	63,0 s	63,0 s
Limit:	Connected after setting delay time ( $\geq 60$ s)	
Gradient:	The maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: disable. For recorded gradient see diagram below.	
f) In frequency range after frequency failure	$\geq 49,50$ Hz for twice of setting observation time	$\leq 50,15$ Hz for twice of setting observation time
Reconnection time [s]	63,0 s	62,0 s
Limit:	Reconnection after setting observation time ( $\geq 60$ s)	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: $10\%P_{E_{max}}/\text{min}$ . For non or partly adjustable generators the connection after trip of the interface protection is delayed by a randomised value between 1 min and 10 min. For recorded gradient see diagram below.	
<p><b>Test:</b>            Test condition b) and c): voltage within the limits of 85% to 110%<math>U_n</math>.            Test condition e): frequency within the limits of 49,50Hz to 50,15Hz.            Test condition f): frequency within the limits of 49,50Hz to 50,15Hz.            In order to avoid continuous starting and disengaging operations of the interface protection relay, the disengaging value of frequency and voltage functions shall be above 2 % deviating from the operate value.</p>		
<p><b>Assessment criterion:</b>            d) the micro generator connects respectively starts generating electrical power only in the permitted range of voltage and frequency and            e) for adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute and            f) for non or partly adjustable generators the connection after trip of the interface protection is delayed by a randomised value between 1 min and 10 min.</p>		
<p><b>Note:</b>            The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.</p>		

Graph of the gradual power supply : Test c) for  $\geq 85\% U_n$




Graph of the gradual power supply : Test c) for  $\leq 110\% U_n$






Graph of the gradual power supply : Test f) for  $\geq 49,50\text{Hz}$



Graph of the gradual power supply : Test f) for  $\leq 50,15\text{Hz}$



### EN 50549-1:2019: Ceasing and reduction of active power on set point

Clause	Test requirement	Test procedure according standard	Result
4.11.1	Ceasing active power	CEI 0-21:2019-04, Annex A.4.3.3.2	<b>P</b>
4.11.2	Reduction of active power on a set point	FGW TG3, Revision 25, clause 4.1.2	<b>P</b>

<b>4.11.1</b>	<b>Ceasing active power</b>	<b>P</b>
---------------	-----------------------------	----------

**Operating time of the monitoring device**

Test:	Remote tripping signal for the external disconnection
Limit [s]:	5 s
Reaction time of the tripping value [s]:	0,350 s


**Note:**  
 The test method refer to Annex A,4,3,2 of CEI 0-21:2019-04,  
 Generating plants shall be equipped with a logic interface (input port) in order to cease active power output within five seconds following an instruction being received at the input port, If required by the DSO, this includes remote operation.  
 The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.

**Graph of Remote trip signal :**



4.11.2 Reduction of active power on set point			P
<b>Test result: ASW50K-LT-G2</b>			
Setpoint power bin [%Pn]	P <sub>set</sub> [kW]	P <sub>60</sub> [kW]	Deviation [%Pn]
100%	50,00	49,593	-0,81
90%	45,00	45,631	1,26
80%	40,00	40,610	1,22
70%	35,00	35,551	1,10
60%	30,00	30,513	1,03
50%	25,00	25,422	0,84
40%	20,00	20,340	0,68
30%	15,00	15,253	0,51
20%	10,00	10,169	0,34
10%	5,00	5,070	0,14
	Setpoint power bin [%Pn]	Deviation [%Pn]	
Max. deviation	90%	1,26	
<b>Limit <math>\Delta P_{E60}/P_{Setpoint}</math>:</b>	<b>+ 5 % of P<sub>E<sub>max</sub></sub></b>		
<b>Test:</b>			
The setpoint signal must be reduced from 100% to 0% Pn:			
a) for adjustable PGUs in increments of 10% Pn, 1 minute must elapse after every change to the setpoint setting so that the PGU can settle at the new setpoint, Then the active power of the PGU must be measured as a 1-min mean value.			
b) For all other PGUs, in line with their adjustable steps, 5 minutes must elapse after the setpoint setting is changed so that the PGU can settle at the new setpoint, Then the active power of the PGU must be measured as a 1-min mean value.			
<b>Assessment criterion:</b>			
a) for adjustable PGUs:			
- no network disconnection			
- the active power value does not exceed the setpoint by more than 5% P <sub>E<sub>max</sub></sub>			
- the setting time determined this way is ≤ 1min			
b) For all other PGUs:			
- the active power value does not exceed the setpoint by more than 5% P <sub>E<sub>max</sub></sub> or			
- the setpoint is fallen below within 5 minutes or the PGU has switched off			
<b>Note:</b>			
The setting time is ≤ 1min. See below "Graph of the setting accuracy".			
The tests had been performed on the ASW50K-LT-G2 are valid for the ASW30K-LT-G2, ASW33K-LT-G2, ASW36K-LT-G2, ASW40K-LT-G2 and ASW45K-LT-G2 since it is same as in hardware and just power derated by software.			

Graph of active power on set point



## EN 50549-1:2019

Clause	Test requirement	Test procedure according standard	Result
4.13	Requirements regarding single fault tolerance of interface protection system and interface switch	VDE V 0124-100:2019-02 (Draft), clause 5.5.2	<b>P</b>

4.13 Requirements regarding single fault tolerance of interface protection system and interface switch								P
Component No.	Fault	Test condition		Test time	Fuse No,	Fault condition		Result
		AC	DC			AC	DC	
RY501 defect	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error code E03" Relay check Fail" No damage, No hazard.
RY502 defect	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error code E03" Relay check Fail" No damage, No hazard.
RY503 defect	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error code E03" Relay check Fail" No damage, No hazard.
RY504 defect	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error code E03" Relay check Fail" No damage, No hazard.
RY505 defect	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error code E03" Relay check Fail" No damage, No hazard.
RY506 defect	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error code E03" Relay check Fail" No damage, No hazard.
L1 grid voltage monitor R501 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L1 grid voltage monitor R503 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L1 grid voltage monitor R544 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L1 grid voltage monitor R543 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.

4.13 Requirements regarding single fault tolerance of interface protection system and interface switch								P
Component No.	Fault	Test condition		Test time	Fuse No,	Fault condition		Result
		AC	DC			AC	DC	
L2 grid voltage monitor R505 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L2 grid voltage monitor R508 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L2 grid voltage monitor R545 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L2 grid voltage monitor R547 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L3 grid voltage monitor R509 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L3 grid voltage monitor R512 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L3 grid voltage monitor R548 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
L3 grid voltage monitor R550 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error code E34 "grid voltage fault" No damage, no hazard.
PV voltage monitor R107 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.
PV voltage monitor R106 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.



4.13 Requirements regarding single fault tolerance of interface protection system and interface switch								P
Component No.	Fault	Test condition		Test time	Fuse No,	Fault condition		Result
		AC	DC			AC	DC	
PV voltage monitor R102 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.
PV voltage monitor R133 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.
PV voltage monitor R137 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.
PV voltage monitor R136 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.
PV voltage monitor R128 defect	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.
PV voltage monitor R130 defect	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error cord E36 "PV input voltage fault" No damage, no hazard.
PV array insulation resistance monitoring, Q114, C to E	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
PV array insulation resistance monitoring, R364	Open before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
PV array insulation Resistance monitoring, R365	Open before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
PV array insulation resistance monitoring, R343	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.

4.13 Requirements regarding single fault tolerance of interface protection system and interface switch								P
Component No.	Fault	Test condition		Test time	Fuse No,	Fault condition		Result
		AC	DC			AC	DC	
PV array insulation resistance monitoring, R352	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
PV array insulation resistance monitoring, R348	open before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
PV array insulation resistance monitoring, RY101(Pin5.8)	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
PV array insulation resistance monitoring, RY102(Pin3.4)	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
PV array insulation resistance monitoring, C275	Short before start-up	230V 0,5A	850V 0,1A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord E38 " PV array's insulation" No damage, No hazard.
GFCI detect, Q501(Pin C-E)	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord 163 " GFCI Redundancy check" No damage, No hazard.
GFCI detect, R515	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord 163 " GFCI Redundancy check" No damage, No hazard.
GFCI detect, R515	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord 163 " GFCI Redundancy check" No damage, No hazard.
GFCI detect, C522	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord 163 " GFCI Redundancy check" No damage, No hazard.
GFCI detect, C522	Open	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord 163 " GFCI Redundancy check" No damage, No hazard.

4.13 Requirements regarding single fault tolerance of interface protection system and interface switch								P
Component No.	Fault	Test condition		Test time	Fuse No,	Fault condition		Result
		AC	DC			AC	DC	
GFCI detect, CT501 Pin5-6	Short	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter can not start-up. Error cord 163 " GFCI Redundancy check" No damage, No hazard.
Main CPU, U523	Short +3,3V power supply pin to GND	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error message "167 CPU self-test --RAM abnormal". No damage, No hazard.
Main CPU, U516	Short +1,2V power supply pin to GND	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error message "167 CPU self-test --RAM abnormal". No damage, No hazard.
Main CPU, U516	Oscillat orshort	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error message "167 CPU self-test --RAM abnormal". No damage, No hazard.
Communication between DSPs	open R962	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error message "167 CPU self-test --RAM abnormal". No damage, No hazard.
Slave CPU, U546	Short +3,3V power supply pin to GND	230V 59,4A	850V 52,0A	2min	--	230V 0,5A	850V 0,1A	PV inverter disconnected from grid immediately. Error message "167 CPU self-test --RAM abnormal". No damage, No hazard.
The errors in the control circuit simulate that the safety is even under one error ensured,								
<b>Addendum – Shutdown device</b>								
Each active phase can be switched, (L and N)								Yes
If no galvanic separation between AC and DC (PV): Two relays in series on each active phase are necessary to fulfil the basic insulation or simple separation based on the PV working voltage,								Two relays in series on each active phase
<b>Note:</b>								



Report No.: PV2107WDG0438

# Annex No. 1

## Datasheet of the relay

# G7EB

## 功率继电器

### 实现AC480V 100A开关的高温支持型大容量功率继电器

- 实现最大AC480V-100A的大容量开关
- 最高环境温度可达85°C
- 实现高耐冲击电压(线圈和接点之间)10kV
- 接点间隔3.6mm以上(符合VDE0126)
- 实现初始5mΩ以下的低接触电阻



符合RoHS

#### 型号标准

G7EB-□ □ □

① ② ③

① 接点极数

1: 1极

② 接点构成

A: a接点

③ 端子形状

无标记: 标准型

P1: 特殊端子型

#### 用途示例

- 太阳能变频器
- 工业变频器
- UPS(不间断电源)

G  
7  
E  
B

#### 种类

端子形状	接点构成	保护结构	型号	线圈额定电压(V)	最小包装单位
标准型	1a	耐助焊剂型	G7EB-1A	DC12	60个/箱
特殊端子型			G7EB-1AP1	DC24	

注. 订购时, 请注明线圈额定电压(V)。

例: G7EB-1A DC12

□ 额定线圈电压

此外, 交付时的包装标记及标注的电压规格为□□VDC。

#### 额定值/性能

##### 额定值

##### ●操作线圈

项目	额定电流(mA)	线圈电阻(Ω)	动作电压(V)	复位电压(V)	最大容许电压(V)	功耗(mW)
			额定电压的百分比			
DC12	约235.3	51	75%以下*	5~32%	120% (23°C时)	约2,800 约575*
DC24	约116.5	206				

注1. 额定电流、线圈电阻的值指的是线圈温度为+23°C时的值, 公差±10%。

注2. 动作特性指的是线圈温度为+23°C时的值。

注3. 最大容许电压指的是在环境温度为+23°C时继电器线圈操作电源的电压容许变化范围内的最大值。

\* 使用保持电压时的线圈功耗约为575mW(保持电压45%时)。详情请参阅第4页的“●关于继电器动作后的线圈电压降低(保持电压)”。

\* 部分安装方向不在保证范围内。详情请参阅第4页的“●安装方向性”。

##### ●开关部(接点部)

项目	阻性负载
接点结构	双断开
接点材质	Ag合金
额定负载	AC480V 100A/AC800V 40A
额定通电流	100A
接点电压的最大值	AC800V
接点电流最大值	100A

# G7EB

## 功率继电器

### 性能

项目	型号	G7EB-1A、G7EB-1AP1
接触电阻 *1		5mΩ以下
动作时间 *2		30ms以下
复位时间 *2		10ms以下
绝缘电阻 *3		1,000MΩ以上
耐电压	线圈和接点间	AC5,000V 50/60Hz 1min
	同极接点间	AC2,000V 50/60Hz 1min
耐冲击电压		线圈和接点间 10kV(1.2×50μs)
振动	耐久	10~55~10Hz 单振幅0.75mm(双振幅1.5mm)
	误动作	励磁: 10~55~10Hz 单振幅0.75mm(双振幅1.5mm) 无励磁: 10~55~10Hz 单振幅0.15mm(双振幅0.3mm)
冲击	耐久	1,000m/s <sup>2</sup>
	误动作	励磁: 100m/s <sup>2</sup> 无励磁: 50m/s <sup>2</sup>
耐久性	机械	100万次以上(开关频率10,800次/h)
	电气(阻性负载) *4	①AC480V 100A 300次 85℃ ②AC800V 40A 冲击、通电100A、断路40A 30,000次 85℃ (开关频率1秒ON-9秒OFF)
故障率P水准(参考值) *5		DC5V 1A
使用条件	线圈保持电压 *6	线圈额定电压的45~65%
	使用环境温度	-40℃~85℃(不结冰、凝露)
	使用环境湿度	5~85%RH
重量		约100g

注: 上述值为23℃的初始值。(电气耐久性除外)

\*1. 测量条件: DC6V 20A 电压下降法。

\*2. 测量条件: 外加额定操作电压时不包括接点跳动。

\*3. 测量条件: 用DC1000V 绝缘电阻计测量与耐电压项目中相同的部位。


\*4. 使用二极管与齐纳二极管时, 请将二极管和齐纳二极管接至继电器线圈。

详情请参阅4页的“关于操作线圈与二极管连接”。

\*5. 此值为开关频率180次/min时的值。

\*6. 使用保持电压的详情请参阅第4页的“●关于继电器动作后的线圈电压降低(保持电压)”。

### 误动作冲击




测量: 往3轴6个方向各加3次冲击, 测定接点产生误动作的值。

但是, 励磁电压须在保持电压额定值范围内。

规格值: 励磁 100m/s<sup>2</sup>

无励磁 50m/s<sup>2</sup>

### 冲击方向



# G7EB


## 功率继电器

### 外形尺寸


CAD数据 标记的商品备有2维CAD图、3维CAD模型的数据。  
CAD数据可从网站 <https://www.ecb.omron.com.cn> 下载。

(单位: mm)

#### 标准型 G7EB-1A



#### 特殊端子型 G7EB-1AP1



G  
7  
E  
B

### 国际标准认证额定值

国际标准认证的额定值与个别指定的性能值不同, 请仔细确认后再使用。

UL标准认证型号: (文件No. E41515)

型号	接点构成	操作线圈额定值	接点额定值	认证开关次数
G7EB-1A G7EB-1AP1	1a	12, 24V DC	800VAC 100A通电, 55A 断路85°C	6,000次

EN/IEC、TÜV标准认证型号 (批准No. R50416743)

型号	接点构成	操作线圈额定值	接点额定值	认证开关次数
G7EB-1A G7EB-1AP1	1a	12, 24V DC	800VAC 100A (Resistive)	200次

CQC标准认证型号 (批准No. CQC18002207225)

型号	接点构成	操作线圈额定值	接点额定值	认证开关次数
G7EB-1A G7EB-1AP1	1a	12, 24V DC	800VAC 100A (Resistive)	200次

# G7EB

## 功率继电器

### 请正确使用

●有关如何正确使用,请参见“印刷基板用继电器共通注意事项”部分。


#### 使用注意事项

##### ●安装方向性

·根据动作特性和电气耐久性能,本继电器的安装方向有一定限制。

请勿在非下图指定的方向安装使用。

非指定的安装可能会导致动作不良和非预期老化引起的烧损。




##### ●关于继电器动作后的线圈电压降低(保持电压)

·该继电器请务必在保持电压下使用。

·请如下图所示,首先对线圈施加额定电压0.1秒~3秒。

·请将线圈的额定电压设定为额定电压的100~120%、保持电压设定为额定电压的45~65%,避免因线圈电压变动等而超出上述范围。



	线圈施加电压	线圈电阻*	线圈功耗
额定电压	100~120%	51Ω	约2.8~4.0W
保持电压	45~65%		约0.57~1.2W

\* 线圈电阻值指的是线圈温度为+23℃时的值,公差±10%。


##### ●关于操作线圈与二极管连接

·请将二极管及齐纳二极管(或可变电阻)接至继电器线圈(见下图)。二极管为线圈浪涌吸收用。仅使用二极管可能会影响开关性能,因此请与齐纳二极管组合使用。

·线圈无极性,因此安装二极管时,请使其极性与线圈的施加电压相反。

·齐纳二极管的推荐齐纳电压是线圈额定电压的3倍。

·二极管的反向耐压为线圈额定电压的10倍以上,因此请使用正向电流超过线圈额定电流的二极管。



##### ●关于印刷基板端子的焊接

·请使用焊接槽在290℃下、20秒内完成焊接。

·并非密封结构,因此继电器不可整体清洗。

##### ●关于安装

·应尽可能选择在干燥且尘埃、有毒气体较少的场所进行安装。

·高温多湿和有毒气体环境中,会因结露和腐蚀生成物的影响,导致性能劣化。从而导致继电器主体故障与烧损。

·产品的重量约为100g。请充分注意印刷基板的强度。

并且为了减少热应力导致的焊接裂缝,请使用双面穿孔印刷基板。

##### ●关于坠落

·本继电器发生坠落时,请勿使用。

##### ●关于电气耐久性

·本继电器为交流高压规格,在超出记载的接点额定值、电气耐久性规格范围的状态下持续使用时,可能会导致异常发热、起火。请勿在超出记载范围的条件上使用或用于非交流高压的用途。

·本产品的电气耐久性是在本公司规定的标准试验状态下使用阻性负载时的负载开关次数。

根据线圈驱动电路、周围环境、开关频率、负载条件(在感性负载和电容负载下使用),也可能发生寿命降低、断路不良,请务必在实际设备上确认。

##### ●关于微小负载开关

·本继电器为功率继电器,适用于交流高压的开关用途。请勿用于信号用途等微小负载开关。

订购前请务必阅读我司网站上的“注意事项”。

### 欧姆龙电子部品(中国)统辖集团

网站

欧姆龙电子部件贸易(上海)有限公司

<https://www.ecb.omron.com.cn>

Cat. No. J236-CN5-02

2019年12月

© OMRON Corporation 2019 All Rights Reserved.  
规格等随时可能更改,恕不另行通知。

18  
10





Report No.: PV2107WDG0438

# Annex No. 2

## Pictures of the unit

**Photo of EUT**

**Enclosure front view**



**Enclosure side view**



**Photo of EUT**

**Enclosure side view**



**Enclosure side view**



**Photo of EUT**

**Enclosure bottom view**




**Enclosure rear view**




**Photo of EUT**

**Internal view - 1**




**Internal view - 2**



**Photo of EUT**

**Internal view - 3**




**PCB view - 1**



Photo of EUT

PCB view – 2




PCB view – 3



**Photo of EUT**

**PCB view – 2**



**PCB view – 5**







Photo of EUT

PCB view – 6





Report No.: PV2107WDG0438

# Annex No. 3

## Test Equipment list

Date(s) of performance test: 2021-07-29 to 2021-09-12

Equipment	Internal No,	Manufacturer	Type	Serial No,	Calibration is valid to
ScopeCorder	ZSCG30466	YOKOGAWA	DL850E	//	June, 07, 2022
Power analyzer	C3RB17008E	YOKOGAWA	WT1800	//	June, 09, 2022
AC Source	SCGJ110	CHROMA	61512	//	Monitored by Power analyzer
DC Simulation Power supply	62150EF01657	CHROMA	62150H-1000S	//	
	ESCGJ770	CHROMA	62180H-1800S	//	
	ESCGJ771	CHROMA	62180H-1800S	//	
	ESCGJ772	CHROMA	62180H-1800S	//	
	ESCGJ773	CHROMA	62180H-1800S	//	
ESCGJ774	CHROMA	62180H-1800S	//		
AC/DC Current probel	SCGJ347	Tektronix	A622	//	June, 07, 2022
Temp. & Humi. Recorder	2	//	HTC-1	//	2022-06-21
Power analyzer	SCGJ025	YOKOGAWA	WT3000	//	June, 09, 2022



Report No.: PV2107WDG0438

# End of Test Report