

Certificate of Conformity

By the product certificate number:

No. 2622/0240-A-CER

Issued to:

License holder:

AISWEI Technology (Shanghai) Co., Ltd.
Room 905B, 757 Mengzi Road, Huangpu District,
200023 Shanghai, P.R. China



Trademark:



Manufacturer:

AISWEI New Energy Technology (YangZhong) Co., Ltd.
No. 588 Gangxing Road, Yangzhong, Zhenjiang, China

It is certified that the product:

Type of generating unit: **Grid-connected PV Inverter**

| Models: | ASW5000-S | ASW6000-S | ASW8000-S | ASW10000-S |
|------------------------|---|-----------|-----------|------------|
| Technical Data: | | | | |
| Nominal power [W] | 5000 | 6000 | 8000 | 10000 |
| Nominal voltage [V] | 230 | 230 | 230 | 230 |
| Nominal frequency [Hz] | 50 | 50 | 50 | 50 |
| Firmware version | Master Software version: V610-01053-04 Slave Firmware version: V610-01054-04 Safety Firmware version: V610-10009-04 | | | |
| Number of phases | Single Phase | | | |
| Isolation Transformer | No | | | |

Is in compliance with the standard:

IEC 61727: 2004

Photovoltaic (PV) systems – Characteristics of the utility interface.

This certificate is based upon the test results of the Test Report GZES220300424001

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-32 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 31st May 2022

This certificate is valid until 31st May 2027

Madrid, 31st May 2022



Daniel Arranz Muñiz
Certification Manager

